



April 14, 2017

Lewisville Independent School District
340 Lake Haven
Lewisville, Texas 75057
Attn: Mr. Paul Siddall

Re: Limited Mold Assessment Services
Flower Mound Elementary School
Room 102, Principal's Office &
Art Room
4101 Churchill
Flower Mound, Texas
LISD PO No. 91730030-00
Apex Project No. 725010727068

Introduction

Apex TITAN, Inc., a subsidiary of Apex Companies, LLC (APEX) conducted limited mold assessment activities for the Lewisville Independent School District (Lewisville I.S.D.) within Flower Mound Elementary School located at 4101 Churchill in Flower Mound, Texas (hereinafter referred to as the "Site"). The investigation was limited to areas of the Site identified by Lewisville I.S.D. as described below. The assessment was performed by Mr. Clinton S. Jech, a State of Texas licensed Mold Assessment Technician (Lic. No. MAT1075) on April 6, 2017. Apex's mold services definitions and limitations are included as an attachment to this report.

Investigation Areas

Lewisville I.S.D. identified the following physical portions of the Site as the target investigation areas ("Investigation Areas") for mold assessment: readily accessible areas within room 102, principal's office and the art room. Apex's mold assessment services were limited to the Investigation Area(s) identified by Lewisville, I.S.D. Additional areas or portions of the Site were out-of-scope and not included in Apex's mold assessment or this report at this time.

Scope of Work

As set forth in Apex's Mold Assessment Proposal (No. P725010727078) dated April 5, 2017. Apex's scope-of-work was to provide visual and/or analytical mold assessment and related services in the Investigation Areas which included:

Visual Reconnaissance: Apex performed a visual reconnaissance of the Investigation Areas for visible indications of moisture intrusion (as indicated by staining or visible moisture) and/or suspect mold growth. Apex's visual reconnaissance only included readily accessible or visible portions of the Investigation Areas.

Suspect Mold Growth Sampling and Analysis: Apex collected limited ambient air samples for nonviable mold spores utilizing Air-O-Cell cassettes. "Air-O-Cell" refers to slit impaction air sampling cassettes manufactured by Zefon Analytical Accessories, St. Petersburg, Florida.

Site Reconnaissance Observations/Findings and Recommendations

Apex's Mold Assessment Site reconnaissance was performed on April 6, 2017 by Mr. Clinton S. Jech. Apex's visual reconnaissance of the Investigation areas revealed the following:

Temperature and Relative Humidity

Temperature readings collected inside the rooms ranged from 73.5 to 75.9 degrees Fahrenheit while relative humidity ranged from 28.9 to 33.0 percent. Temperature readings collected outside the building ranged from 74.7 to 78.9 degrees Fahrenheit while outside relative humidity ranged from 14.6 to 1.5 percent.

Relative humidity is a measure of the moisture content of air and is closely tied to the comfort of the office/workplace temperature. As with temperature, there are no regulations governing acceptable office/workplace humidity ranges. Humidity levels in the office/workplace are not only related to health effects, but also have operational impacts on modern office equipment.

Workplace/office temperatures have historically been considered a subjective factor because the perception of uncomfortable temperature levels is specific to each individual. There are no regulations governing acceptable office/workplace temperature ranges, but significant research has been conducted which indicates that there are temperature ranges that are not only comfortable but also result in optimum performance. ASHRAE (American Society of Heating, Refrigerating & Air Conditioning Engineers) has published guidelines describing thermal environmental conditions that at least 80% of the persons who occupy that environment will find acceptable or “comfortable.” Table I below explains the applicable limits and guidelines.

Table I Acceptable Ranges of Temperature and Humidity		
Relative Humidity	Winter Temperatures	Summer Temperatures
30%	68.5 to 76°F	74 to 80°F
40%	68.5 to 75.5°F	73 to 79.5°F
50%	68.5 to 74.5°F	73 to 79°F
60%	68 to 74°F	72.5 to 78°F

Apex utilized a Protimeter Moisture Measurement System (MMS) instrument (Model No. BLD2000) to measure and diagnose dampness in the drywall within random areas. The MMS is a battery powered handheld unit that is equipped with hydrostick probes to measure moisture content in wood, drywall and other and non-conductive materials. The device measures electrical conductivity of building materials and compares the conductivity readings to an internal, electronic standard reading for normal or “dry” materials.

Moisture content readings were obtained by pushing the moisture probe pins into surfaces. The measured values were then displayed on a colored scale depicting if the materials measured were normal (dry), higher than normal but not critical (at risk) or contained excessive moisture levels (wet). Based on the manufacturer’s guidelines, the instrument measurement values are described below:

< 5%	Out of Range
> 5% but < 16%	Normal
> 17% but < 20%	Higher than Normal but Not Critical
> 20%	Excessive Moisture Levels

Moisture meter readings taken from the walls within the rooms ranged from 7-10% which is considered normal by the manufacturer.

Air Monitoring Results

Apex collected three (3) samples from the interior of the investigation area and two (2) samples from the exterior of the building. The microbial samples were analyzed by Steve Moody Micro Services, LLC (SMMS) in Farmers Branch, Texas; SMMS is a State of Texas licensed mold analysis laboratory and accredited under the AIHA Laboratory Quality Assurance Program for Environmental Microbiology.

Air testing performed using spore traps indicated that total airborne mold spores in the classroom was lower as compared to those measured outside of the building at the time the sampling was performed. The total fungal spore concentration within the investigation areas ranged from 274 to 629 counts/m³, while the exterior level ranged from 3,061 to 3,441 counts/m³.

Room 102

Seven types of mold were identified at a higher concentration within the investigation area as compared to the samples collected from the exterior of the building. Air sample(s) collected within room 102 reported Hyphal/Spore Fragments - Dematiaceous as 200 counts/m³ while exterior levels were reported as 113 counts/m³, Drechslera/Bipolaris Group as 80 counts/m³ while exterior levels were reported as 47 counts/m³ and Curvularia as 40 counts/m³ while exterior levels were reported as 7 counts/m³. In addition, Aspergillus/Penicillium was reported as 27 counts/m³, Nigrospora as 7 counts/m³, Torula as 7 counts/m³ and Pithomyces as 7 counts/m³ while no exterior levels were reported.

Principal's Office

Two types of mold were identified at a higher concentration within the investigation area as compared to the samples collected from the exterior of the building. Air sample(s) collected within the Principal's Office reported Curvularia as 13 counts/m³ while exterior levels were reported as 7 counts/m³ and Aspergillus/Penicillium as 7 counts/m³ while no exterior levels were reported.

Art Room

Three types of mold were identified at a higher concentration within the investigation area as compared to the samples collected from the exterior of the building. Air sample(s) collected within the Art room reported Alternaria as 60 counts/m³ while exterior levels were reported as 47 counts/m³, Curvularia as 13 counts/m³ while exterior levels were reported as 7 counts/m³ and Aspergillus/Penicillium as 7 counts/m³ while no exterior levels were reported.

The American Conference of Governmental Industrial Hygienists (ACGIH) sets forth assessment criteria related to the "indoor/outdoor" relationship where the indoor air quality should be at or below that of outdoor air quality with regard to fungal spores (see ACGIH Bioaerosols, Assessment and Controls publication, 1999).

Suspect Mold

No visible mold was observed during the assessment. No excessive dust or odors were noted during the inspection.

Conclusions and Recommendations

Based on Apex's limited assessment and the analytical results collected, it appears that the indoor air quality, as it relates to airborne fungi was within recommended guidelines on the day

of the assessment. However, due to the high amounts of Hyphal/Spore Fragments identified in room 102, Apex recommends that the room be retested in approximately six (6) weeks.

If you have any questions regarding this report or if we can assist you with any other matter, please contact the undersigned at (469) 365-1140.

Sincerely,
Apex TITAN, Inc.



Clinton S. Jech
Manager, Field Services
Texas Mold Assessment Technician, Lic. No. MAT1075



Darren G. Bowden
Senior Program Manager
Texas Mold Assessment Consultant Lic. No. MAC0321

Attachments: Analytical Results/Chain of Custody, Mold Services Definitions & Limitations

ATTACHMENT 1

Analytical Results/Chain of Custody



IAQ Mold Report

Summary

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas	Lab Job No. : 17F-04270
Project : Flower Mound ES Room 102 and Principal's Office	Report Date : 04/10/2017 11:32 AM
Project # : 725010727068	Sample Date: 04/06/2017
Sample Type: Spore Trap, Non-cultured	Spore Trap Type: Zefon - Air-O-Cell
Test Method: Mold: ASTM D7391-09 - Standard Profile	Page 1 of 3

On 4/6/2017, five (5) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
1	150	Exterior, South Entry * See Analytical Notes report for further details	Cladosporium	2180 71%
			Basidiospores	354 12%
			Ascospores	307 10%
			Hyphal / Spore Fragments - Dematiaceous	113 4%
			Alternaria	47 2%
			Coprinus group	20 <1%
			Myxomycete / Rust / Smut	13 <1%
			Epicoccum	13 <1%
			Spegazzinia	7 <1%
			Cercospora	7 <1%
			Total:	3061 100%
2	150	Exterior * See Analytical Notes report for further details	Cladosporium	3000 87%
			Ascospores	120 3%
			Basidiospores	113 3%
			Hyphal / Spore Fragments - Dematiaceous	47 1%
			Drechslera / Bipolaris group	47 1%
			Myxomycete / Rust / Smut	40 1%
			Alternaria	40 1%
			Coprinus group	13 <1%
			Cercospora	7 <1%
			Epicoccum	7 <1%
			Curvularia	7 <1%
Total:	3441 100%			



IAQ Mold Report

Summary

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas	Lab Job No. : 17F-04270
Project : Flower Mound ES Room 102 and Principal's Office	Report Date : 04/10/2017 11:32 AM
Project # : 725010727068	Sample Date: 04/06/2017
Sample Type: Spore Trap, Non-cultured	Spore Trap Type: Zefon - Air-O-Cell
Test Method: Mold: ASTM D7391-09 - Standard Profile	Page 2 of 3

On 4/6/2017, five (5) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
3	150	Room 102	Hyphal / Spore Fragments - Dematiaceous	200 32%
			Basidiospores	140 22%
			Drechslera / Bipolaris group	80 13%
			Cladosporium	47 7%
			Curvularia	40 6%
			Myxomycete / Rust / Smut	27 4%
			Aspergillus / Penicillium	27 4%
			Alternaria	27 4%
			Ascospores	13 2%
			Nigrospora	7 1%
			Torula	7 1%
			Pithomyces	7 1%
			Epicoccum	7 1%
4	150	Principal's Office	Hyphal / Spore Fragments - Dematiaceous	60 22%
			Cladosporium	47 17%
			Drechslera / Bipolaris group	40 15%
			Basidiospores	40 15%
			Alternaria	33 12%
			Myxomycete / Rust / Smut	20 7%
			Curvularia	13 5%
			Epicoccum	7 3%
			Aspergillus / Penicillium	7 3%
			Ascospores	7 3%



IAQ Mold Report

Summary

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-09 - Standard Profile

Lab Job No. : 17F-04270
Report Date : 04/10/2017 11:32 AM
Sample Date: 04/06/2017
Spore Trap Type: Zefon - Air-O-Cell

Page 3 of 3

On 4/6/2017, five (5) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
5	150	ART Room	Hyphal / Spore Fragments - Dematiaceous Basidiospores Alternaria Cladosporium Drechslera / Bipolaris group Myxomycete / Rust / Smut Ascospores Epicoccum Curvularia Aspergillus / Penicillium <div style="text-align: right;">Total:</div>	80 22% 73 20% 60 16% 53 14% 27 7% 20 5% 20 5% 13 3% 13 3% 13 3% 372 100%

Results may not be reported except in full. Data contained in this test report relates only to the samples tested. This report does not express or imply interpretation of the results contained herein. Interpretation should be made by a qualified professional.

Moody Labs assumes no responsibility for the manner in which these samples were collected or handled prior to being received at this laboratory. Moody Labs assumes no responsibility for the qualifications of personnel performing sampling and/or interpretations of this data.

Analyst(s): Mushtaq Khan

Lab Manager : Heather Lopez

Lab Director : Bruce Crabb

Approved Signatory :

Approved Signatory :

Thank you for choosing Moody Labs



IAQ Mold Report

Data Detail

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068
Sample Type: Spore Trap, Non-cultured
Test Method: Mold: ASTM D7391-09 - Standard Profile

Lab Job No. : 17F-04270
Report Date : 04/10/2017 11:32 AM
Sample Date: 04/06/2017
Spore Trap Type: Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:	1				2				3			
Location:	Exterior, South Entry				Exterior				Room 102			
Media Expires On:	Nov 2017				Nov 2017				Nov 2017			
Notes Included:	See Analytical Notes				See Analytical Notes							
Volume:	150				150				150			
	raw ct.	MDL	spores/m ³		raw ct.	MDL	spores/m ³		raw ct.	MDL	spores/m ³	
Alternaria	7	6.67	47	2%	6	6.67	40	1%	4	6.67	27	4%
Ascospores	46	6.67	307	10%	18	6.67	120	3%	2	6.67	13	2%
Aspergillus / Penicillium									4	6.67	27	4%
Basidiospores	53	6.67	354	12%	17	6.67	113	3%	21	6.67	140	22%
Cercospora	1	6.67	7	<1%	1	6.67	7	<1%				
Chaetomium												
Cladosporium	109	20.00	2180	71%	105	28.57	3000	87%	7	6.67	47	7%
Coprinus group	3	6.67	20	<1%	2	6.67	13	<1%				
Curvularia					1	6.67	7	<1%	6	6.67	40	6%
Drechslera / Bipolaris group					7	6.67	47	1%	12	6.67	80	13%
Epicoccum	2	6.67	13	<1%	1	6.67	7	<1%	1	6.67	7	1%
Hyphal / Spore Fragments - Dematiac	17	6.67	113	4%	7	6.67	47	1%	30	6.67	200	32%
Hyphal / Spore Fragments - Hyaline												
Memnoniella												
Myxomycete / Rust / Smut	2	6.67	13	<1%	6	6.67	40	1%	4	6.67	27	4%
Nigrospora									1	6.67	7	1%
Pithomyces									1	6.67	7	1%
Spegazzinia	1	6.67	7	<1%								
Stachybotrys												
Torula									1	6.67	7	1%
TOTALS	241		3061	100%	171		3441	100%	94		629	100%
Analyst	Mushtaq Khan				Mushtaq Khan				Mushtaq Khan			
Analysis Date	4/10/2017				4/10/2017				4/10/2017			
Debris Rating	2				3				4			
Debris Composition												
Fibers	1/5				1/5				2/5			
Inorganic/Other	2/5				3/5				3/5			
Insect Parts	0/5				1/5				0/5			
Pollen	1/5				2/5				1/5			
Skin/Dander	0/5				2/5				4/5			



IAQ Mold Report

Data Detail

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas	Lab Job No. : 17F-04270
Project : Flower Mound ES Room 102 and Principal's Office	Report Date : 04/10/2017 11:32 AM
Project # : 725010727068	Sample Date: 04/06/2017
Sample Type: Spore Trap, Non-cultured	Spore Trap Type: Zefon - Air-O-Cell
Test Method: Mold: ASTM D7391-09 - Standard Profile	

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:	4				5								
Location:	Principal's Office				ART Room								
Media Expires On:	Nov 2017				Nov 2017								
Notes Included:													
Volume:	150				150								
	raw ct.	MDL	spores/m ³		raw ct.	MDL	spores/m ³						
Alternaria	5	6.67	33	12%	9	6.67	60	16%					
Ascospores	1	6.67	7	3%	3	6.67	20	5%					
Aspergillus / Penicillium	1	6.67	7	3%	2	6.67	13	3%					
Basidiospores	6	6.67	40	15%	11	6.67	73	20%					
Cercospora													
Chaetomium													
Cladosporium	7	6.67	47	17%	8	6.67	53	14%					
Coprinus group													
Curvularia	2	6.67	13	5%	2	6.67	13	3%					
Drechslera / Bipolaris group	6	6.67	40	15%	4	6.67	27	7%					
Epicoccum	1	6.67	7	3%	2	6.67	13	3%					
Hyphal / Spore Fragments - Dematiac	9	6.67	60	22%	12	6.67	80	22%					
Hyphal / Spore Fragments - Hyaline													
Memnoniella													
Myxomycete / Rust / Smut	3	6.67	20	7%	3	6.67	20	5%					
Nigrospora													
Pithomyces													
Spegazzinia													
Stachybotrys													
Torula													
TOTALS	41		274	100%	56		372	100%					
Analyst	Mushtaq Khan				Mushtaq Khan								
Analysis Date	4/10/2017				4/10/2017								
Debris Rating	3				4								
Debris Composition													
Fibers	2/5				2/5								
Inorganic/Other	3/5				4/5								
Insect Parts	1/5				1/5								
Pollen	2/5				2/5								
Skin/Dander	3/5				3/5								

End of Data Detail section
17F-04270



IAQ Mold Report

Analytical Notes

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas

Lab Job No. : 17F-04270

Project : Flower Mound ES Room 102 and Principal's Office

Report Date : 04/10/2017 11:32 AM

Project # : 725010727068

Sample Date : 04/06/2017

Sample Type: Spore Trap, Non-cultured

Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

Page 1 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Samples Analyzed

Sample No: 1 : Exterior, South Entry

Notes: Please note: the minimum detection limit for Cladosporium is 20 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.

Sample No: 2 : Exterior

Notes: Please note: the minimum detection limit for Cladosporium is 29 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.

Field Blanks

No discernable field blanks were submitted with this set of samples.

NOTE: All remaining samples suitable for analysis.

Methods

Method: ASTM D7391-09. A standard spore trap reading consists of a 30% reading for small spores; 100% of the sample is read for medium and large spores. A 100% reading is provided for containment samples, upon request, or otherwise as noted. Use final spore concentrations, not raw spore counts, for interpretation of results.

Calculation: Spores/cubic meter = (Raw spore count)*(MDL)

Note: MDL (Minimum Detection Limit) is calculated based upon 1 raw spore count.

Moody Labs recommends two significant figures for calculated values based on ASTM D7391-09.

This report must not be used by the customer to claim product certification, approval, or endorsement by AIHA, ISO, or any agency of the Federal Government.

Debris Rating Key

0 - No linear trace detected

1 - Trace particulate/debris

2 - Light particulate/debris

3 - Moderate particulate/debris.

4 - Substantial particulate/debris

5 - Extensive particulate/debris

6 - Field blank

10 - Hold Sample

11 - Modified Analysis per Client Instructions

NOTE: Particulate/debris are defined as skin, fibers, pollen grains, insect parts, fungal and/or other non-fungal particles.



IAQ Mold Report

Analytical Notes

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas

Project : Flower Mound ES Room 102 and Principal's Office

Project # : 725010727068

Sample Type: Spore Trap, Non-cultured

Test Method: Mold: ASTM D7391-09 - Standard Profile

Lab Job No. : 17F-04270

Report Date : 04/10/2017 11:32 AM

Sample Date : 04/06/2017

Spore Trap Type: Zefon - Air-O-Cell

Page 2 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.



LAB # 102577



End of Analytical Notes section

17F-04270

IAQ Mold Report


Supplemental Overview

DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Moody Labs
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068

Lab Job No. 17F-04270
Report Date 04/10/2017 11:32 AM
Sample Date : 04/06/2017





2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview


DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068

Lab Job No. 17F-04270
Report Date 04/10/2017 11:32 AM
Sample Date : 04/06/2017

Exterior, South Entry

■ Sample ■ Average Reference 1 □ Average Reference 2



Average Reference 1 = Exterior, South Entry, Exterior



2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068

IAQ Mold Report


Supplemental Overview

DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Lab Job No. 17F-04270
Report Date 04/10/2017 11:32 AM
Sample Date : 04/06/2017

Exterior

■ Sample ■ Average Reference 1 □ Average Reference 2



Average Reference 1 = Exterior, South Entry, Exterior



2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview


DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068

Lab Job No. 17F-04270
Report Date 04/10/2017 11:32 AM
Sample Date : 04/06/2017

Room 102

■ Sample ■ Average Reference 1 □ Average Reference 2



Average Reference 1 = Exterior, South Entry, Exterior



2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

IAQ Mold Report

Supplemental Overview


DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Apex Titan, Inc. - Dallas
Project : Flower Mound ES Room 102 and Principal's Office
Project # : 725010727068

Lab Job No. 17F-04270
Report Date 04/10/2017 11:32 AM
Sample Date : 04/06/2017

Principal's Office

■ Sample ■ Average Reference 1 □ Average Reference 2



Average Reference 1 = Exterior, South Entry, Exterior



2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Client : Apex Titan, Inc. - Dallas

Project : Flower Mound ES Room 102 and Principal's Office

Project # : 725010727068

IAQ Mold Report

Supplemental Overview

DSHS License No.: LAB0117
AIHA EMPAT ID: 102577


Lab Job No. 17F-04270

Report Date 04/10/2017 11:32 AM

Sample Date : 04/06/2017

ART Room

■ Sample ■ Average Reference 1 □ Average Reference 2



Average Reference 1 = Exterior, South Entry, Exterior



Chain of Custody

17F- MOCS

Lab Job # ~~17F~~ 04270

Lab Job # _____

Lab Job # _____

Please call in advance for immediate, after-hour, & weekend pricing & availability.

ASBESTOS PLM

Bulk Immediate 1 day 2 day 3 day 5 day

Analyze All Positive Stop

PCM Air (7400)

Immediate 1 day 2 day 3 day 5 day

TOTAL DUST(0500/0600)

1 day 2 day

ASBESTOS TEM

Air AHERA Method Late Night* 6 hr 12 hr 24 hr

Air 7402 (Modified) 1 day 2 day 3 day

Bulk 1 day 2 day 3 day 5 day

Water/Wipe/Micro Vac 1 day 2 day 3 day

Analyze Blanks Yes No

*Late night analysis surcharges apply

MOLD

Direct Exam Immediate 1 day 2 day

Standard Air Immediate 1 day 2 day

Expanded Air Immediate 1 day 2 day

Culture** 10-14 days

Analyze Blanks Yes No

Turnaround of Culture Samples subject to Culture Growth

BACTERIA**

Colony Counts (CC) 3 day 5 day

CC + Gram Stain 3 day 5 day

Coliform & E. coli (P/A) 2-3 day

Legionella 14 days

OTHER:

Billing Company / City: Apex Titan, Inc

Submitter's Company:

Submitter's Name: Clinton S. Tech

Project: Flower Mound E3 Room 102 and Principals office

Contact Information: Name: Clint Tech

E-mail Results to: Clint/Darren/Veronica

Invoice Address: Veronica

of Samples: ^{CS} 5

Sample Date: 4/6/2017

Project #: 725010727068

Phone #: _____

Mobile #: (972) 989-1031

Fax #: _____

P.O. #: _____

Please review paperwork and samples before submitting to lab. Unsealed / improperly packaged / damaged / expired samples or excessive administrative requests may incur additional fees

Notes:

Sample #	Sample Description	Vol. / Area (if applicable)	Location / Notes
1	Exterior, South Entry	150	T=78.9 ° H=14.6%
2	Exterior,	150	T=74.7 ° H=17.5%
3	Room 102	150	T=75.9 ° H=31.2% M=7-10 % Ceilings = Ceiling Tile Walls = Sheetrock Floors = Carpet
4	Principals office	150	T=73.7 ° H=28.9% M=7-10 % Ceilings = Ceiling Tile Walls = Sheetrock Floor = Carpet
5	ART Room	150	T=73.5 ° H=33.0% M=8-10 % Ceilings = Ceiling Tile Walls = Sheetrock Floors = Floor Tile

Released By:	Date / Time: 4/6/2017 1515	Received By:	Date / Time: 4/6/17 3:16pm
Released By:	Date / Time:	Received By:	Date / Time:

ATTACHMENT 2

Mold Services Definitions & Limitations/Standard of Care and Reliance



Mold Services Definitions & Limitations

“Mold” defined. Mold is a general term used to describe various types of singled-celled naturally occurring biological organisms occurring worldwide. For purposes of this report the term “mold” is broadly defined to include any living or dead fungi or related products or parts, including spores, hyphae, and mycotoxins.

Limited Scope of Mold Assessment. The scope of Apex’s mold assessment services as reflected in the Proposal and this report are limited in that (i) they were physically limited to certain portions of the building structure (e.g., the Client identified Investigation Areas); and (ii) limited by accessibility to building materials or components within the Investigation Area(s). In contrast to a Limited Assessment” is a comprehensive assessment, which involves destructive sampling methods and the scope of the assessment typically extending to the entire building structure.

Time sensitive. Mold assessments are essentially a “snap shot in time,” and the results are only relevant at the time of site reconnaissance. Because mold, when biologically active, is a living organism, its presence is influenced and controlled by environmental conditions. Mold assessments, therefore, are “time sensitive” in that the presence and concentration of mold and similar organisms in building structures or in the air is directly influenced by environmental conditions (such as humidity, moisture, nutrients and substrates), whether natural or caused by man, which conditions may vary significantly over relatively short periods of time.

Methodologies. Currently, mold assessment methodologies and protocols are governed by persuasive guidelines (rather than promulgated federal/state or local regulations). Presently, there is no data that supports a threshold limit or dose-response relationship for exposure to mold aeroallergens, individual pathogens, opportunistic pathogens and/or mycotoxins. The Occupational Safety and Health Administration (OSHA), the National Institute of Occupational Safety and Health (NIOSH) and other non-governmental associations, have not yet established permissible exposure limits (PELs), recommended exposure limits (RELs), or other limit values for aeroallergens. Because no limit values presently exist, Apex will not and cannot represent that the site contains no harmful microbes, mold, fungi, or their metabolites, or other latent conditions beyond those identified by the limited scope of this mold assessment.

Findings limited. Findings from a limited mold assessment are limited because of the nature of the information obtained (e.g., visual reconnaissance of readily accessible areas of building structures, interview information, anecdotal information, and limited sampling data derived from one or more specific sampling events). Apex cannot warrant the accuracy of prior or subsequent information/data, reports and services performed by other firms at the Site. Apex assumes no responsibility or liability for errors in information or data provided by or through the client or third party sources. Apex’s services are not to be construed as legal or medical interpretation or advice.

Moisture Intrusion Limitation. Apex performs mold assessment services and is not a moisture intrusion, HVAC, roofing, plumbing or building envelope specialist. However, during the course of conducting its mold assessment services, Apex will report observed areas of apparent moisture intrusion. Apex does not and will not investigate the cause or causes of such observed moisture intrusion. In the event apparent moisture intrusion is observed, Apex will recommend

that the client contact a specialist (i.e., plumbing contractor, building envelope specialist, HVAC contractor, water intrusion specialist, etc.) to assist the client in determining the specific cause or causes of the moisture intrusion and remedial options.

Standard of Care

Apex performed its Services in accordance with generally accepted practices of the profession undertaken in similar services at the same time and in the same geographical area. No other warranties, expressed or implied, apply to the Services hereunder or this report.

Reliance

Apex's proposal for this project, services and this report have been prepared on behalf of and for the exclusive use of Lewisville Independent School District solely for their use and reliance in assessing the presence of mold in the Investigation Areas of the site. Lewisville Independent School District is the only party to which Apex explained the risks and limitations of the services and was solely involved in shaping the scope of services. Accordingly, reliance on this report by any other party may involve assumptions leading to an unintended interpretation of findings and opinions. With the consent of the client, Apex may offer reliance to third parties or contract with other parties to develop findings and opinions related to such party's unique risk management concerns. Notwithstanding the foregoing, reliance by any and all third parties upon the proposal, the Services or this report shall be limited in the aggregate to all relying parties to the fair market value of the Services provided by Apex.