

COMMITTED TO EXCELLENCE

DATE: October 9, 2007

TO: Ruth Eidenier

SUBJECT: Camey ES - IAQ - Test Results for Room 7 & Recommendations

On Thursday 9/20, EFI Air Tested Room 7. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 7 was **76.4%** of the outdoor levels. Utilizing this theory, the indoor concentrations are elevated above acceptable guidelines for areas with filtered air or air conditioning. EFI recommends that the HVAC filter be changed, the fresh-cut flowers in the room be removed, if they are still present and the carpets be steam-cleaned. EFI will follow up with another sampling. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882