

COMMITTED TO EXCELLENCE

**DATE:** August 27, 2007

**TO:** Steve Polzer, Principal

**SUBJECT:** Creekside ES - IAQ - Test Results for C106, C108, C111, A106, A108, B112

On Tuesday 8/14, EFI Air Tested the Rooms C106, C108, C111, A106, A108 and B112. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room C106, was **11.8%**, Room C108 was **30.9%**, Room C111 was **4.8%**, and Room A106 was **4.7%**, Room A106 was **7.1%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. On Room B112, it had high counts of **Aspergillus/Penicillium**. We will have the room steam cleaned over the coming weekend (8/31). We will retest the room around September 6. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Special Projects (IAQ)  
469-446-8882