

COMMITTED TO EXCELLENCE

DATE: February 15, 2008

TO: Steve Polzer, Principal

SUBJECT: Creekside ES - IAQ - Test Results for Room C-110

On Tuesday 2/12, EFI Air Tested the Room C-110. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room C-110, was **92.4%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are elevated above the guidelines for areas with filtered air or air conditioning. EFI recommends that the cabinet be remediated. After talking with you and that cabinet doesn't pose to be a health hazard at this time, we will plan to do the remediation starting at 4:00 PM on Friday 3/14. This will give our Projects Department time to do the Build Back during Spring Break. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
469-446-8882