

COMMITTED TO EXCELLENCE

DATE: August 26, 2007

TO: Patrick Schott, Principal

SUBJECT: Forest Vista ES - IAQ - Test Results for Room 607

On Monday 8/20, EFI Air Tested Room 607. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 607 was **10.1%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882