

COMMITTED TO EXCELLENCE

DATE: September 6, 2007

TO: Felicia Sprayberry, Principal

SUBJECT: Hebron Valley ES - Test results for Room C7

On Thursday 8/30, EFI Air Tested Room C7. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room C7 was **11.1%** of the outdoor levels. Because there was 1 mold spore of chaetomium, EFI recommends that the room be steam cleaned. Then we would have it re-tested in a week. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882