

COMMITTED TO EXCELLENCE

DATE: October 22, 2007

TO: Sherry Wagner, Principal

SUBJECT: Highland Village ES – IAQ – Test Results for the Music Room

On Wednesday 10/17, EFI Air Tested the Music room. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Music room was **1.7%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882