

COMMITTED TO EXCELLENCE

DATE: December 4, 2007

TO: Linda Holman, Principal

SUBJECT: Liberty ES - IAQ - Test Results for Room 428

On Wednesday 11/28, EFI Air Tested Room 428. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 428 was **67.3%** of the outdoor levels. Because there is elevated mold count, EFI recommends that the room be steam cleaned. Custodial will steam clean Room 428 on Friday night 12/7. Then we will have it re-tested in a week. I have also copied Mark Ross on this, so that he can have the Contractor mitigate the water intrusion. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882