

COMMITTED TO EXCELLENCE

DATE: March 27, 2008

TO: Jennifer Mattingly, Principal

SUBJECT: McAulliffe ES - IAQ - Test Results for Room A-114

On Friday 3/14, EFI Air Tested Room A-114. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room A-114, was **43.6%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,

Paul

Paul Siddall

Special Projects (IAQ)

Facility Services

469-446-8882