

COMMITTED TO EXCELLENCE

DATE: August 27, 2007

TO: Rita Bacque, Principal

SUBJECT: Morningside ES - IAQ - Test Results for Portable #5

On Monday 8/20, EFI Air Tested Portable #5. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Portable #5 was **10.1%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882