

COMMITTED TO EXCELLENCE

DATE: August 28, 2007

TO: Robin Macke, Principal

SUBJECT: Wellington ES - IAQ - Concerns of mold in Portable rooms 7 & 8

I received your E-mail of 8/27. This morning 8/28, I visited Wellington ES and inspected Portable rooms 7 & 8. The AC air duct louvers have dust and possible mold on them. I have requested the HVAC department to clean them. I talked to Fritz Youder, and he will have a person out there today 8/28, to clean the louvers and replace the filters. I will also be requesting EFI to Air Test those two classrooms Thursday 8/30. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
469-446-8882