

## Limited Mold Assessment Hicks Elementary Nurses Office

Treadway, David <treadwayd@lisd.net>

Mon 9/18/2023 9:35 AM

To:Rehfuss, Tracy <rehfusst@lisd.net>;Kown, Alexander <kowna@lisd.net>

Cc:Braumuller, Colleen <braumullerca@lisd.net>;Hughes, Jason <hughesjk@lisd.net>;Jones, Steven <jonessa@lisd.net>;Cashman, Jinger <cashmans@lisd.net>

Mrs. Rehfuss,

Good morning. On 9/11/23, Ensolum LLC conducted a limited mold assessment in the nurse's office per a campus request. It is typically assumed that indoor spore levels in an area with filtered or air-conditioned air, and activity levels associated with schools, average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the nurse's office was 4% of the outdoor levels. Utilizing this theory, the indoor concentrations were well within acceptable guidelines for areas with filtered or air-conditioned air. The final report will be available on the LISD website as soon as I receive it from the vendor. Please let me know if you have any questions.

Sincerely,

David Treadway

David Treadway

LISD Environmental Coordinator

Facility Services Department



September 18, 2023

Lewisville Independent School District  
1597 Edmonds Lane  
Lewisville, Texas 75067  
Attn: David Treadway

**Re: Limited Mold Assessment Report**  
Hicks Elementary School – Rm. A103 – Nurse’s Office  
3651 Compass Drive  
Frisco, TX 75034  
Ensolum Project No. 01A1288193

Ensolum, LLC (Ensolum) was retained to perform limited mold assessment services within Rm. A103 – Nurse’s Office of Hicks Elementary School, located at 3651 Compass Drive in Frisco, Texas. Enclosed is the report, including analytical data.

Ensolum appreciates this opportunity to be of service and looks forward to our continued work together. Please contact the undersigned with any questions or concerns you may have.

Sincerely,

Nolan Domain  
Mold Assessment Consultant  
MAC1479

Darren G. Bowden  
Principal  
MAC0321 EXP: 2/15/2024

## 1.0 INTRODUCTION

Ensolum was retained by David Treadway, LISD, to complete a Limited Mold Assessment within Rm. A103 – Nurse’s Office of Hicks Elementary School located at 3651 Compass Drive in Frisco, Texas. The purpose of this investigation was to determine if elevated concentrations of airborne fungal spores and structures were present within the above-referenced areas. Ensolum completed the on-site investigation on September 11, 2023. The Limited Mold Assessment was performed in response to a complaint of possible indoor air quality issues within specific areas.

## 2.0 PROCEDURE

Ensolum visually inspected accessible areas of room A103 - Nurse’s Office. Water damage was observed in the following locations:

VISIBLE WATER DAMAGE		
LOCATION	DATE	EXPLANATION
Outdoor Front	9/11/2023	N/A
Nurse’s Office	9/11/2023	No water damage observed
Outdoor South	9/11/2023	N/A

Following the inspection of potential water-damaged building materials, Ensolum conducted a moisture investigation in the identified areas to determine if nonvisible water-damaged materials and other building materials within the investigation area were present. The moisture investigation was completed with an Extech M0260 moisture meter on accessible porous and semi-porous building materials in each area of concern. At the time of investigation, monitored building materials did not exhibit elevated moisture concentrations in comparison with similar and non-affected building materials in the structure and standard scientific guidelines.

Representative Relative Humidity readings were collected and recorded using an Extech Instruments Humidity / Temperature Pen. Measurements recorded during the investigation are listed in the chart below:

TEMPERATURE, RELATIVE HUMIDITY & SPECIFIC HUMIDITY				
LOCATION	DATE	Temperature: F	Relative Humidity	Specific Humidity
Outdoor Front	9/11/2023	80 °F	38%	58 GPP
Nurses Room	9/11/2023	74 °F	40%	50 GPP
Outdoor South	9/11/2023	85 °F	35%	63 GPP



Area air samples were collected with spore trap cassettes and analyzed for airborne fungal spores and structures. Samples were collected at a rate of 15 liters per minute. Indoor air sample(s) were collected for a five (5) minute period (75 liters) at a height of approximately five (5) feet above finished floor (AFF). Outdoor air samples were collected for a five (5) minutes period (75 liters) at a height of approximately five (5) feet above level ground. American Conference of Governmental Industrial Hygienists (ACGIH) guidelines were followed for the sample collection. Fungal air samples were collected in the following areas:

SPORE TRAP LOCATIONS	
SAMPLE NUMBER	LOCATION
ST-1	Outdoor Front
ST-2	Nurse's Office
ST-3	Outdoor South

### 3.0 RESULTS

Currently, there are no regulatory standards for airborne fungal contamination. Therefore, results of the fungal analysis are compared against scientific guidelines. Bioaerosol samples are evaluated by comparing the indoor samples against the outdoor sample. The same types of fungi should be found in both the indoor and outdoor samples.

Should higher fungal concentrations occur in the indoor sample(s) or complaint areas, this generally indicates there is a source of fungal growth in the area. The types of fungi are also evaluated-the same types/genus of fungi should be present in both the indoor/complaint and outdoor/non-complaint samples.

The results of the fungal air samples collected were evaluated. Air testing performed using spore traps found that airborne mold spores within the investigation area were considerably lower and were qualitatively like those measured outside of the building at the time the sampling was performed.

### CONCLUSIONS

Based on ENSOLUM's limited assessment and the analytical results, it appears that the indoor air quality, as it relates to airborne fungi, was within recommended guidelines on the day of the assessment.

## APPENDIX A

### ANALYTICAL DATA



# IAQ Mold Report

## Summary

TDLR License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC**Project :** LISD, Hicks ES**Project # :** 01A 1288 193**Sample Type:** Spore Trap, Non-cultured**Test Method:** Mold: MLQ - 0112 - Standard Profile**Lab Job No. :** 23F-10981**Report Date :** 09/13/2023**Sample Date:** 09/11/2023**Spore Trap Type:** Zefon - Air-O-Cell

Page 1 of 2

On 9/11/2023, three (3) samples were submitted by a representative of Ensolum, LLC (located at 8330 LBJ Freeway, Suite 830 8330 LBJ Freeway, Suite 830, Dallas, TX 75243) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
ST-1	75	Outdoor Front * See Analytical Notes report for further details	Cladosporium Basidiospores Paecilomyces Ascospores Aspergillus / Penicillium Coprinus group Hyphal / Spore Fragments - Dematiaceous Alternaria Cercospora / Pseudocercospora Myxomycete / Periconia / Rust / Smut Drechslera / Bipolaris / Helminthosporium / Exserohilum group Fusarium Curvularia Hyphal / Spore Fragments - Hyaline Torula Nigrospora Pithomyces  Total:	3800 51% 986 13% 560 7% 520 7% 320 4% 240 3% 240 3% 227 3% 173 2% 133 2% 107 1% 67 <1% 67 <1% 40 <1% 13 <1% 13 <1% 13 <1%  7519 100%
ST-2	75	Nurses Room	Aspergillus / Penicillium Hyphal / Spore Fragments - Dematiaceous Ascospores Basidiospores Nigrospora Pithomyces Alternaria  Total:	93 37% 53 21% 40 16% 27 11% 13 5% 13 5% 13 5%  252 100%





## IAQ Mold Report

### Summary

TDLR License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC**Project :** LISD, Hicks ES**Project # :** 01A 1288 193**Sample Type:** Spore Trap, Non-cultured**Test Method:** Mold: MLQ - 0112 - Standard Profile**Lab Job No. :** 23F-10981**Report Date :** 09/13/2023**Sample Date:** 09/11/2023**Spore Trap Type:** Zefon - Air-O-Cell

Page 2 of 2

On 9/11/2023, three (3) samples were submitted by a representative of Ensolum, LLC (located at 8330 LBJ Freeway, Suite 830 8330 LBJ Freeway, Suite 830, Dallas, TX 75243) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
ST-3	75	Outdoor South * See Analytical Notes report for further details	Cladosporium Basidiospores Aspergillus / Penicillium Ascospores Hyphal / Spore Fragments - Dematiaceous Alternaria Myxomycete / Periconia / Rust / Smut Cercospora / Pseudocercospora Coprinus group Paecilomyces Drechslera / Bipolaris / Helminthosporium / Exserohilum group Curvularia Fusarium Hyphal / Spore Fragments - Hyaline  Total:	2914 42% 1413 21% 893 13% 453 7% 240 3% 173 3% 147 2% 147 2% 120 2% 107 2% 93 1% 80 1% 67 <1% 40 <1% 6887 100%

This report shall not be reproduced except in full, without approval of the laboratory. Data contained in this test report relates only to the samples tested. This report does not express or imply interpretation of the results contained herein. Interpretation should be made by a qualified professional. Moody Labs assumes no responsibility for the manner in which these samples were collected or handled prior to being received at this laboratory. Volume, area, and/or weight is provided by the customer. Moody Labs assumes no responsibility for the qualifications of personnel performing sampling and/or interpretations of this data.

**Analyst(s):** Dylan Milholen**Lab Director :** Heather Lopez**Approved Signatory :****Lab Director :** Bruce Crabb**Approved Signatory :**

End of Summary section (23F-10981)

Thank you for choosing Moody Labs

SMLMS v13.83





# IAQ Mold Report

## Data Detail

TDLR License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane  
Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC  
**Project :** LISD, Hicks ES  
**Project # :** 01A 1288 193  
**Sample Type:** Spore Trap, Non-cultured  
**Test Method:** Mold: MLQ - 0112 - Standard Profile

**Lab Job No. :** 23F-10981**Report Date :** 09/13/2023**Sample Date:** 09/11/2023 Page 1 of 1**Spore Trap Type:** Zefon - Air-O-Cell

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:	ST-1					ST-2					ST-3				
Location:	Outdoor Front					Nurses Room					Outdoor South				
Media Expires On:	Jul 2024					Jul 2024					Jul 2024				
Notes Included:	See Analytical Notes										See Analytical Notes				
Volume:	75					75					75				
	Raw Ct	RL	spores/m <sup>3</sup>	%Total	spores/m <sup>2</sup> SF	Raw Ct	RL	spores/m <sup>3</sup>	%Total	spores/m <sup>2</sup> SF	Raw Ct	RL	spores/m <sup>3</sup>	%Total	spores/m <sup>2</sup> SF
Alternaria	17	13	227	3%	230	1	13	13	5%	10	13	13	173	3%	170
Ascospores	39	13	520	7%	520	3	13	40	16%	40	34	13	453	7%	450
Aspergillus / Penicillium	24	13	320	4%	320	7	13	93	37%	90	67	13	893	13%	890
Basidiospores	74	13	986	13%	990	2	13	27	11%	30	106	13	1413	21%	1400
Cercospora / Pseudocercospora	13	13	173	2%	170						11	13	147	2%	150
Chaetomium															
Cladosporium	114	33	3800	51%	3800						102	29	2914	42%	2900
Coprinus group	18	13	240	3%	240						9	13	120	2%	120
Curvularia	5	13	67	<1%	70						6	13	80	1%	80
Drechslera / Bipolaris / Helminthosporium /	8	13	107	1%	100						7	13	93	1%	90
Fusarium	5	13	67	<1%	70						5	13	67	<1%	70
Hypheal / Spore Fragments - Dematiaceou	18	13	240	3%	240	4	13	53	21%	50	18	13	240	3%	240
Hypheal / Spore Fragments - Hyaline	3	13	40	<1%	40						3	13	40	<1%	40
Myxomycete / Periconia / Rust / Smut	10	13	133	2%	130						11	13	147	2%	150
Nigrospora	1	13	13	<1%	10	1	13	13	5%	10					
Paecilomyces	42	13	560	7%	560						8	13	107	2%	100
Pithomyces	1	13	13	<1%	10	1	13	13	5%	10					
Stachybotrys															
Torula	1	13	13	<1%	10										
TOTALS	393		7519	100%	7500	19		252	100%	250	400		6887	100%	6900
Analyst	Dylan Milholen					Dylan Milholen					Dylan Milholen				
Analysis Date	9/13/2023					9/13/2023					9/13/2023				
Debris Rating	3					3					3				
Debris Composition															
Fibers	1/5					2/5					1/5				
Inorganic/Other	3/5					2/5					3/5				
Insect Parts	1/5					0/5					1/5				
Pollen	1/5					1/5					1/5				
Skin/Dander	1/5					3/5					1/5				

End of Data Detail section  
23F-10981

SMLMS v13.83





## IAQ Mold Report

### Analytical Notes

TDLR License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC

**Project :** LISD, Hicks ES

**Project # :** 01A 1288 193

**Sample Type:** Spore Trap, Non-cultured

**Test Method:** Mold: MLQ - 0112 - Standard Profile

**Lab Job No. :** 23F-10981

**Report Date :** 09/13/2023

**Sample Date :** 09/11/2023

**Spore Trap Type:** Zefon - Air-O-Cell

Page 1 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

### Samples Analyzed

**Sample No** ST-1 : Outdoor Front

**Notes:** Please note: the minimum reporting limit for Cladosporium is 33 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.

**Sample No** ST-3 : Outdoor South

**Notes:** Please note: the minimum reporting limit for Cladosporium is 29 spores / cubic meter. When comparing results to other samples, use calculated results, not raw numbers.

### Field Blanks

No discernable field blanks were submitted with this set of samples.

**NOTE: All remaining samples suitable for analysis.**

### Methods

Method: MLQ - 0112 / ASTM D7391: Categorization and Quantification of Airborne Fungal Structures in an Inertial Impaction.

Sample by Optical Microscopy.

Samples are read at 100% under 400x magnification unless noted. Partial readings may be employed when concentrations are elevated. Use final spore concentrations, not raw spore counts, for interpretation of results.

Calculation: Spores/cubic meter = (Raw spore count)\*(RL)

Note: RL (Reporting Limit) is based upon 1 raw spore count.

Moody Labs recommends two significant figures for calculated values based on ASTM D7391.

This report must not be used by the customer to claim product certification, approval, or endorsement by AIHA LAP, LLC, ISO, or any agency of the Federal Government.

### Debris Rating Key

0 - No linear trace detected

1 - Trace particulate/debris

2 - Light particulate/debris

3 - Moderate particulate/debris

4 - Substantial particulate/debris

5 - Extensive particulate/debris

6 - Field blank

10 - Hold Sample

11 - Modified Analysis per Client Instructions

NOTE: Particulate/debris are defined as skin, fibers, pollen grains, insect parts, fungal and/or other non-fungal particles.



## IAQ Mold Report

### Analytical Notes

TDLR License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC

**Project :** LISD, Hicks ES

**Project # :** 01A 1288 193

**Sample Type:** Spore Trap, Non-cultured

**Test Method:** Mold: MLQ - 0112 - Standard Profile

**Lab Job No. :** 23F-10981

**Report Date :** 09/13/2023

**Sample Date :** 09/11/2023

**Spore Trap Type:** Zefon - Air-O-Cell

Page 2 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.



Lab ID # 102577



**SBA WOSB**  
Woman Owned Small Business



TEXAS DEPARTMENT OF TRANSPORTATION

Small Business Enterprise Program

End of Analytical Notes section

23F-10981

certified  
**WBENC**  
WOMEN'S BUSINESS ENTERPRISE



# IAQ Mold Report


## Supplemental Overview

TDLR License No.: LAB0117  
AIHA EMPAT ID: 102577

**Moody Labs**  
2051 Valley View Lane  
Farmers Branch, TX 75234 Phone: (972) 241-8460

**Lab Job No.** 23F-10981  
**Report Date** 09/13/2023  
**Sample Date :** 09/11/2023

**Client :** Ensolum, LLC  
**Project :** LISD, Hicks ES  
**Project # :** 01A 1288 193





# IAQ Mold Report

## Supplemental Overview



2051 Valley View Lane  
Farmers Branch, TX 75234 Phone: (972) 241-8460


TDLR License No.: LAB0117  
AIHA EMPAT ID: 102577

**Client :** Ensolum, LLC  
**Project :** LISA, Hicks ES  
**Project # :** 01A 1288 193

**Lab Job No.** 23F-10981  
**Report Date** 09/13/2023  
**Sample Date :** 09/11/2023

Outdoor Front

■ Sample   ■ Average Reference 1   □ Average Reference 2



Average Reference 1 = Outdoor Front

Average Reference 2 = Outdoor South

# IAQ Mold Report

## Supplemental Overview

TDLR License No.: LAB0117  
AIHA EMPAT ID: 102577


2051 Valley View Lane  
Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC  
**Project :** LISD, Hicks ES  
**Project #:** 01A 1288 193

**Lab Job No.** 23F-10981  
**Report Date** 09/13/2023  
**Sample Date :** 09/11/2023

Nurses Room

■ Sample      ■ Average Reference 1      □ Average Reference 2



Average Reference 2 = Outdoor South

Average Reference 1 = Outdoor Front

# IAQ Mold Report

## Supplemental Overview

TDLR License No.: LAB0117  
AIHA EMPAT ID: 102577




2051 Valley View Lane  
Farmers Branch, TX 75234 Phone: (972) 241-8460

**Client :** Ensolum, LLC  
**Project :** LISD, Hicks ES  
**Project #:** 01A 1288 193

**Lab Job No.** 23F-10981  
**Report Date** 09/13/2023  
**Sample Date :** 09/11/2023

Outdoor South

■ Sample  
■ Average Reference 1  
■ Average Reference 2



Average Reference 1 = Outdoor Front  
Average Reference 2 = Outdoor South





# Chain of Custody

Lab Job # 23F-10981  
 Lab Job # Std AOC-3  
 Lab Job # \_\_\_\_\_

AFTER HOURS / WEEKEND WORK: ☐ YES ☐ NO

\*Please call in advance for after hours / immediate pricing & availability\*

Page \_\_\_\_ of \_\_\_\_

## ASBESTOS PLM

Bulk ☐ Immediate ☐ 1 day ☐ 2 day ☐ 3 day ☐ 5-7 day  
☐ Analyze All ☐ Positive Stop

## PCM Air (7400)

☐ Immediate ☐ 1 day ☐ 2 day ☐ 3 day ☐ 5 day  
 Analyze Blanks ☐ Yes ☐ No

## TOTAL DUST(0500/0600)

☐ 1 day ☐ 2 day

## ASBESTOS TEM

Air AHERA Method ☐ Late Night\* ☐ 6 hr ☐ 12 hr ☐ 24 hr  
 Air 7402 (Modified) ☐ 1 day ☐ 2 day ☐ 3 day  
 Bulk ☐ 1 day ☐ 2 day ☐ 3 day ☐ 5 day  
 Water/Wipe/Micro Vac ☐ 1 day ☐ 2 day ☐ 3 day  
 Analyze Blanks ☐ Yes ☐ No

\*Late night analysis surcharges apply

Billing Company / City:

Ensolum LLC

# of Samples:

3 Sample Date: 9-11-23

Project:

LISD-HICKS ES

Project #:

OLA 1288 193

Contact Information: Name:

Dalven

Phone #:

E-mail Results to:

Ensolum.com

Mobile #:

2148439931

Invoice Address:

P.O. #:

\*Please review paperwork and samples before submitting to lab. Unsealed / Improperly packaged / damaged / expired samples or excessive administrative requests may incur additional fees\*

Notes:

Sample #	Sample Description	Vol. / Area (if applicable)	Location / Notes
ST-1	3656 1872 H=37.5 T=80	75	OUT DOOR FLOYT
ST-2	3656 1764 H=39.8 T=74.1	75	Nurses Room
ST-3	3656 1873 H=34.6 T=85.1 Time 10:35	75	OUT DOOR SOUTH
<div> <div>Released By: <u>Nolan Dorman</u> Date / Time: <u>9/11/23 1350</u></div> <div>Released By: _____ Date / Time: _____</div> </div> <div> <div>Received By: <u>[Signature]</u> Date / Time: <u>9/11/23 1350</u></div> <div>Received By: _____ Date / Time: _____</div> </div>			

## APPENDIX B

### DEFINITIONS AND LIMITATION



# ENSOLUM

## Mold Services Definitions & Limitations

Ensolum performed services in accordance with generally accepted practices of the profession undertaken in similar services at the same time and in the same geographical area. No other warranties, express or implied, apply to the services hereunder or the final report.

Ensolum's services and any report have been prepared on behalf of and for the exclusive use of the Client solely for its use and reliance in assessing the presence of mold in the Investigation Areas of the site. The Client was the only party to which Ensolum explained the risks and limitations of the services and was solely involved in shaping the scope of services. Accordingly, reliance on this report by any other party may involve assumptions leading to an unintended interpretation of findings and opinions. With the consent of the Client, Ensolum may offer reliance to third parties or contract with other parties to develop findings and opinions related to such party's unique risk management concerns. Notwithstanding the foregoing, reliance by any and all third parties upon this deliverable, Ensolum's services or any subsequent report shall be limited in the aggregate to the fair market value of the services provided by Ensolum.

"Limited Mold Assessment". This deliverable uses the term "Limited Mold Assessment" to denote that Ensolum's mold assessment services are limited: (i) to certain portions of the building structure (e.g., the Investigation Areas), by non-destructive sampling methodologies, and/or by access limitations to building materials or components within the Investigation Area(s). In contrast to a "Limited Assessment" is a comprehensive assessment would involve destructive sampling methods with the assessment to be conducted throughout the entire building structure.

Time sensitive. One must keep in mind that mold assessments are essentially a "snap shot in time," and the results are only relevant at the time of site reconnaissance. Because mold, when biologically active, is a living organism, its presence is influenced and controlled by environmental conditions. Mold assessments, therefore, are "time sensitive" in that the presence and concentration of mold and similar organisms in building structures or in the air is directly influenced by environmental conditions (such as humidity, moisture, nutrients and substrates), whether natural or caused by man, which conditions may vary significantly over relatively short periods of time.

Methodologies. Currently, mold assessment methodologies and protocols in Texas are governed by persuasive guidelines (rather than promulgated federal/state or local regulations). Presently, there is no data that supports a threshold limit or dose-response relationship for exposure to mold aeroallergens, individual pathogens, opportunistic pathogens and/or mycotoxins. The Occupational Safety and Health Administration (OSHA), the National Institute of Occupational Safety and Health (NIOSH) and other non-governmental associations, have not yet established permissible exposure limits (PELs), recommended exposure limits (RELs), or other limit values for fungi. Because no limit values presently exist, Ensolum will not and cannot represent that the site contains no harmful microbes, mold, fungi, or their metabolites, or other latent conditions beyond those identified by the limited scope of this mold assessment.





Findings limited. Findings in an LMA are limited due to the nature of the information obtained such as a visual reconnaissance of readily accessible areas of building structures, interview information, anecdotal information, and limited sampling data derived from one or more specific sampling events. Ensolum cannot warrant the accuracy of prior or subsequent information/data, reports and services performed by other firms at the Site. Ensolum assumes no responsibility or liability for errors in information or data provided by or through the client or third party sources. Ensolum's services are not to be construed as legal or medical interpretation or advice.

Moisture Intrusion Limitation. Ensolum performs mold assessment services and is not a moisture intrusion, HVAC, plumbing or building envelope specialist. However, during the course of conducting its mold assessment services, Ensolum will report observed areas of apparent moisture intrusion. Ensolum does not and will not investigate the cause or causes of such observed moisture intrusion. In the event apparent moisture intrusion is observed, Ensolum will recommend that the client contact a specialist (i.e., plumbing contractor, building envelope specialist, HVAC contractor, water intrusion specialist, etc.) to assist the client in determining the specific cause or causes of the moisture intrusion and remedial options.

Certificate of Mold Damage Remediation (CMDR). For mold remediation projects (above certain size thresholds), applicable Texas law (i.e., Texas Occupation Code Section 1958.54 and T.A.C. Section 295.397 (the Texas Mold Assessment and Remediation Rules), requires that a "Certificate of Mold Damage Remediation" be issued by the Mold Remediation Contractor upon successful completion of the project. This certificate must be provided to property owners no later than the 10<sup>th</sup> day after the date on which the mold remediation is completed at a property. The Mold Remediation Certificate issued by the Mold Remediation Contractor must include a certification by the Mold Assessor that the mold remediation project has been successfully completed in accordance with the mold remediation protocol.

Be advised that Ensolum's issuance of a CMDR upon successful completion of a Mold Remediation project does not mean, warrant or otherwise guarantee that mold will not be subsequently found in any portion of an Investigation Area or the Site. In the event that Ensolum is engaged to render services in connection with a mold remediation project, ENSOLUM will require Client to provide to Ensolum written documentation that all sources of moisture which contributed to the presence of mold in the Investigation Area have been fully remediated and corrected prior to achieving clearance.

## APPENDIX B

### LICENSES



**TEXAS DEPARTMENT OF LICENSING AND REGULATION**

P.O. Box 12157  
Austin, Texas 78711-2157  
1-800-803-9202 (512) 463-6599  
[www.tdlr.texas.gov](http://www.tdlr.texas.gov)

If you cut around the border of the license it will fit in  
a standard 5" x 7" frame.

**ENSOLUM, LLC**  
**SUITE 1203**  
**2351 W NORTHWEST HWY**  
**DALLAS TX 75220-4433**

*Rick Figueroa*  
Chair

*Thomas F. Butler*  
Vice Chair



*Gerald R. Callas, M.D., F.A.S.A.*  
*Helen Callier*  
*Nora Castañeda*  
*Joel Garza*  
*Gary F. Wesson, D.D.S., M.S.*

*Mold Assessment Company*

**ENSOLUM, LLC**

2351 W NORTHWEST HWY SUITE 1203 DALLAS

License Number: ACO1138

The entity named above is licensed by the Texas Department of Licensing and Regulation.


License Expires: February 07, 2024

Brian E. Francis  
Executive Director






Texas Department of Licensing and Regulation  
Mold Assessment Consultant  
Darren G Bowden  
License No. MAC0321 Expires February 15, 2024



*Rick Figueroa*  
*Chair*

*Thomas F. Butler*  
*Vice Chair*



*Gerald R. Callas, M.D., F.A.S.A.*  
*Helen Callier*  
*Nora Castañeda*  
*Joel Garza*  
*Gary F. Wesson, D.D.S., M.S.*

*Mold Analysis Laboratory*

**MOODY LABS LLC**

2051 VALLEY VIEW LN FARMERS BRANCH

License Number: LAB0117

The entity named above is licensed by the Texas Department of Licensing and Regulation.

License Expires: March 01, 2024

Mike Arismendez, Jr.  
Executive Director

*Rick Figueroa*  
Chair

*Thomas F. Butler*  
Vice Chair



*Gerald R. Callas, M.D., F.A.S.A.*  
*Helen Callier*  
*Nora Castañeda*  
*Joel Garza*  
*Gary F. Wesson, D.D.S., M.S.*

*Mold Assessment Consultant*  
**NOLAN R DOMAIN**

License Number: MAC1479

The person named above is licensed by the Texas Department of Licensing and Regulation.

License Expires: November 09, 2023

Brian E. Francis  
Executive Director