

DATE: April 23, 2018

TO: Barbara Leigh, Manager

SUBJECT: Bolin - IAQ - Air Test Report - Sylvia Martinez's Office

On Thursday 4/19, Apex-Titan Air tested Sylvia Martinez's Office. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Sylvia Martinez's Office, was **12.7%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
340 Lake Haven Rd
Lewisville, TX 75057