

DATE: May 13, 2019

TO: Robert Fisher, Assistant Principal

SUBJECT: Briarhill MS - IAQ - Air Test Results - Rooms 301, 400 & 403

On Thursday 5/9, Ensolum LLC Air tested Rooms 301, 400, 403. It is typically assumed that indoor spore levels in an area with filtered or air-conditioned air, and activity levels associated with schools' average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 301, was **4.3%**, Room 400, was **3.3%**, Room 403, was **4.8%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
340 Lake Haven Rd
Lewisville, TX 75057