

**DATE:** May 24, 2019

**TO:** Dr. Kathy Talbert, Executive Director

**SUBJECT:** Purnell Support Center - IAQ - Air Test - Room 108, JoAnn Dion's Office,  
Ellen Garza's Office and Stage behind Room 108

Ensolum, LLC will be retesting Room 108, JoAnn Dion's Office, Ellen Garza's Office and the Stage behind Room 108.

The Air Tests should be done May 28-May 30 and we should have the results by Monday, June 3.

If you have any questions, please call me.

Thanks,

Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
601 E. Purnell Street  
Lewisville, TX 75057  
Cell: 469-446-8882

**DATE:** June 4, 2019

**TO:** Dr. Kathy Talbert, Executive Director

**SUBJECT:** Purnell Support Center - IAQ - Air Test Results - Room 108, JoAnn Dion's Office, and Stage behind Room 108

On Thursday 5/30, Ensolum LLC Air tested Room 108, JoAnn Dion's Office, and Stage behind Room 108. It is typically assumed that indoor spore levels in an area with filtered or air-conditioned air, and activity levels associated with schools' average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 108, was **0.9%**, in JoAnn Dion's Office, was **1.6%**, in the Stage behind Room 108, was **6.5%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
340 Lake Haven Rd  
Lewisville, TX 75057