

DATE: October 5, 2017

TO: Shawn Barr, Director

SUBJECT: Facility Services - IAQ - Air Test results - Jason Hughes' Office

On Monday 10/2, Apex-Titan Air tested Jason Hughes' Office. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Jason Hughes' Office, was **0.93%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
340 Lake Haven Rd
Lewisville, TX 75057