

**DATE:** November 3, 2017

**TO:** Lisa Lingren, Principal

**SUBJECT:** Bridlewood ES - IAQ - Air Test - Gym, Library, Cafeteria

On Wednesday 11/1, Apex-Titan Air tested in the Gym, Library and Cafeteria. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Gym, was **6.4%**, in the Library, was **1.7%**, and in the Cafeteria, was **34.0%** of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
340 Lake Haven Rd  
Lewisville, TX 75057