

DATE: November 29, 2017

TO: Jason Mullin, Assistant Principal

SUBJECT: Marcus HS - IAQ - Retest Air Test Results - Rooms C-108 & C-110

On Friday 11/17, Apex-Titan Air retested Rooms C-108 & C-110. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room C-108, was **243.3%**, in Room C-110, was **6.4%** of the outdoor levels. Utilizing this theory, the indoor concentrations in Room C-108 are within the acceptable guidelines for areas with filtered air or air conditioning. **Room C-108 is 22.6 % less mold than the October 18 test. We will retest Room C-108 in 4 months.** If you have any questions, please call me.

Thanks,

Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
340 Lake Haven Rd
Lewisville, TX 75057