

**DATE:** December 14, 2018

**TO:** Kelly Roden, Principal

**SUBJECT:** Garden Ridge - IAQ - Air Test Results - Room 203

On Wednesday 12/12, Apex-Titan Air tested Room 203. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 203, was **30.4%** of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
340 Lake Haven Rd  
Lewisville, TX 75057