

**DATE:** December 18, 2018

**TO:** David Lyons, Director of Purchasing

**SUBJECT:** LISD Admin-Purchasing - IAQ - Initial Contact - Philip Talbert's office

Sharon Haney asked me about Air Testing Philip Talbert's office. She said that were concerns about the air in Philip Talbert's office and was causing issues.

I have setup a Work Order, and a P.O. to have the office Air Tested. Ensolum, LLC will be doing the Air Test on a day that it is not raining and above 60 degrees outside.

If you have any questions, please contact me.

Thanks,

Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
340 Lake Haven Rd  
Lewisville, TX 75057  
Cell: 469-446-8882

**DATE:** January 8, 2019

**TO:** David Lyons, Director of Purchasing

**SUBJECT:** LISD ADMIN - Purchasing - IAQ - Air Test Results - Phillip Talbert's Office

On Thursday 12/20, Ensolum LLC Air tested Phillip Talbert's Office. It is typically assumed that indoor spore levels in an area with filtered or air-conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Phillip Talbert's Office, was 6.9% of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. However, due to the presence of 1 raw count of Stachybotrys, additional sampling will be done for a higher level of confidence. In 30 days, I will request another Air Test. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
340 Lake Haven Rd  
Lewisville, TX 75057