

DATE: September 26, 2016

TO: Jeff Brown, Assistant Principal

SUBJECT: Flower Mound HS - IAQ - Results report - Room 2575

On Thursday 9/22, Apex-Titan Air tested Room 2575. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average below the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 2575, was 1.6% of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks, Paul

Paul Siddall Maintenance Energy Auditor (IAQ) Facility Services Lewisville ISD 469-446-8882



DATE: September 19, 2016

TO: Jeffrey Brown, Assistant Principal

SUBJECT: Flower Mound HS - IAQ - Air Test - Room 2575

On Monday 9/19, you had requested an Air Test for Room 2575. I set up W.O. #340423. I am requesting a P.O. to have Apex-Titan Air Test Room 2575. They should be doing the test either Thursday or Friday. We should have the results to you on Monday or Tuesday of next week.

If you have any questions, please contact me.

Thanks, Paul

Paul Siddall Maintenance Energy Auditor (IAQ) Facility Services Lewisville ISD 469-446-8882



September 27, 2016

Lewisville Independent School District 340 Lake Haven Lewisville, Texas 75057 Attn: Mr. Paul Siddall

Re: Limited Mold Assessment Services

Flower Mound High School

Room 2527

3411 Peters Colony Flower Mound, Texas LISD PO # 91703081-00

Apex Project No. 725010727032

Introduction

Apex TITAN, Inc., a subsidiary of Apex Companies, LLC (APEX) conducted limited mold assessment activities for the Lewisville Independent School District (Lewisville I.S.D.) within Flower Mound High School located at 3411 Peters Colony in Flower Mound, Texas (hereinafter referred to as the "Site"). The investigation was limited to areas of the Site identified by Lewisville I.S.D. as described below. The assessment was performed by Mr. Clinton S. Jech, a State of Texas licensed Mold Assessment Technician (Lic. No. MAT1075) on September 22, 2016. Apex's mold services definitions and limitations are included as an attachment to this report.

Investigation Areas

Lewisville I.S.D. identified the following physical portions of the Site as the target investigation areas ("Investigation Areas") for mold assessment: readily accessible areas within room 2527. Apex's mold assessment services were limited to the Investigation Area(s) identified by Lewisville, I.S.D. Additional areas or portions of the Site were out-of-scope and not included in Apex's mold assessment or this report at this time.

Scope of Work

As set forth in Apex's Mold Assessment Proposal (No. P725010727037) dated September 21, 2016. Apex's scope-of-work was to provide visual and/or analytical mold assessment and related services in the Investigation Areas which included:

Visual Reconnaissance: Apex performed a visual reconnaissance of the Investigation Areas for visible indications of moisture intrusion (as indicated by staining or visible moisture) and/or suspect mold growth. Apex's visual reconnaissance only included readily accessible or visible portions of the Investigation Areas.

Suspect Mold Growth Sampling and Analysis: Apex collected limited ambient air samples for nonviable mold spores utilizing Air-O-Cell cassettes. "Air-O-Cell" refers to slit impaction air sampling cassettes manufactured by Zefon Analytical Accessories, St. Petersburg, Florida.

Site Reconnaissance Observations/Findings and Recommendations

Apex'a Mold Assessment Site reconnaissance was performed on September 22, 2016 by Mr. Clinton S. Jech. Apex's visual reconnaissance of the Investigation areas revealed the following:

Temperature and Relative Humidity

Temperature readings collected inside the investigation area were reported as 75.5 degrees Fahrenheit while relative humidity was reported as 37.0 percent. Temperature readings collected outside the building ranged from 86.3 to 88.3 degrees Fahrenheit while outside relative humidity ranged from 36.3 to 39.1 percent.

Relative humidity is a measure of the moisture content of air and is closely tied to the comfort of the office/workplace temperature. As with temperature, there are no regulations governing acceptable office/workplace humidity ranges. Humidity levels in the office/workplace are not only related to health effects, but also have operational impacts on modern office equipment.

Workplace/office temperatures have historically been considered a subjective factor because the perception of uncomfortable temperature levels is specific to each individual. There are no regulations governing acceptable office/workplace temperature ranges, but significant research has been conducted which indicates that there are temperature ranges that are not only comfortable but also result in optimum performance. ASHRAE (American Society of Heating, Refrigerating & Air Conditioning Engineers) has published guidelines describing thermal environmental conditions that at least 80% of the persons who occupy that environment will find acceptable or "comfortable." Table I below explains the applicable limits and guidelines.

Table I							
Acceptable Ranges Of Temperature And Humidity							
Relative Humidity	Winter Temperatures	Summer Temperatures					
30%	68.5 to 76°F	74 to 80°F					
40%	68.5 to 75.5°F	73 to 79.5°F					
50%	68.5 to 74.5°F	73 to 79°F					
60%	68 to 74°F	72.5 to 78°F					

Apex utilized a Protimeter Moisture Measurement System (MMS) instrument (Model No. BLD2000) to measure and diagnose dampness in the drywall within random areas. The MMS is a battery powered handheld unit that is equipped with hydrostick probes to measure moisture content in wood, drywall and other and non-conductive materials. The device measures electrical conductivity of building materials and compares the conductivity readings to an internal, electronic standard reading for normal or "dry" materials.

Moisture content readings were obtained by pushing the moisture probe pins into surfaces. The measured values were then displayed on a colored scale depicting if the materials measured were normal (dry), higher than normal but not critical (at risk) or contained excessive moisture levels (wet). Based on the manufacturer's guidelines, the instrument measurement values are described below:

< 5%	Out of Range
> 5% but < 16%	Normal
> 17% but < 20%	Higher than Normal but Not Critical
> 20%	Excessive Moisture Levels

Moisture meter readings taken from the walls within the investigation areas ranged from 10-13% which is considered normal by the manufacturer.



Air Monitoring Results

Apex collected one (1) sample from the interior of the investigation area and two (2) samples from the exterior of the building. The microbial samples were analyzed by Steve Moody Micro Services, LLC (SMMS) in Farmers Branch, Texas; SMMS is a State of Texas licensed mold analysis laboratory and accredited under the AIHA Laboratory Quality Assurance Program for Environmental Microbiology.

Air testing performed using spore traps indicated that total airborne mold spores in the investigation area were lower as compared to those measured outside of the building at the time the sampling was performed. The total fungal spore concentration within the investigation area was reported as 247 counts/m³, while the exterior level ranged from 14,221 to 15,365 counts/m³.

The American Conference of Governmental Industrial Hygienists (ACGIH) sets forth assessment criteria related to the "indoor/outdoor" relationship where the indoor air quality should be at or below that of outdoor air quality with regard to fungal spores (see ACGIH Bioaerosols, Assessment and Controls publication, 1999).

Suspect Mold

No visible mold was observed during the assessment. No odors or excessive dust were noted.

Conclusions and Recommendations

Based on Apex's limited assessment and the analytical results collected, it appears that the indoor air quality, as it relates to airborne fungi was within recommended guidelines on the day of the assessment.

If you have any questions regarding this report or if we can assist you with any other matter, please contact the undersigned at (469) 365-1140.

Sincerely.

Apex TITAN, Inc.

Clinton S. Jech

Manager, Field Services

Texas Mold Assessment Technician

Lic. No. MAT1075

Darren G. Bowden

Senior Program Manager

Texas Mold Assessment Consultant

Lic. No. MAC0321

Attachments: Analytical Results/Chain of Custody, Mold Services Definitions & Limitations



ATTACHMENT 1

Analytical Results/Chain of Custody





Summary

2051 Valley View Lane Farmers Branch, TX 75234 Phone: (972) 241-8460 DSHS License No.: LAB0117 AIHA EMPAT ID: 102577

Client: Apex Titan, Inc. - Dallas Lab Job No.: 16F-12151

Project: Flower Mound HS Room 2575 Report Date: 09/26/2016 9:30 AM

Sample Type: Spore Trap, Non-cultured Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile Page 1 of 3

On 9/22/2016, three (3) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification		ntration
1	(liters) 150	Exterior, North * See Analytical Notes report for further details	Cladosporium Basidiospores Aspergillus / Penicillium Ascospores Cercospora Myxomycete / Rust / Smut Paecilomyces Fusarium Hyphal / Spore Fragments Curvularia Agaricales group	5450 5250 1120 540 440 374 260 233 193 80 60	38% 37% 8% 4% 3% 3% 2% 1% <1%
			Ganoderma Nigrospora Alternaria Drechslera / Bipolaris group Coprinus group Pyricularia Torula	47 47 40 40 33 7	<1% <1% <1% <1% <1% <1% <1% <1%
			To	otal: 14221	100%



Client:

Project:

Project #:

IAQ Mold Report

Summary

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

725010727032

Sample Type: Spore Trap, Non-cultured

Apex Titan, Inc. - Dallas

Flower Mound HS Room 2575

Lab Job No.: 16F-12151

Report Date: 09/26/2016 9:30 AM

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

Sample Date : 09/22/2016

Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile Page 2 of 3

On 9/22/2016, three (3) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

* See Analytical Notes report for further details Cladosporium Ascospores Aspergillus / Penicillium Resultation Ascospora Aspergillus / Penicillium Resultation R	Sample Number	Volume (liters)	Sample Description	Identification		Concer spores/cu	ntration
		(liters)	Exterior * See Analytical Notes report for	Basidiospores Cladosporium Ascospores Aspergillus / Penicillium Cercospora Paecilomyces Myxomycete / Rust / Smut Hyphal / Spore Fragments Fusarium Curvularia Coprinus group Drechslera / Bipolaris group Agaricales group Alternaria Torula Ganoderma Nigrospora Spegazzinia	Total:	7667 4066 840 820 380 367 360 233 180 87 73 53 53 47 27 13	50% 26% 5% 5% 2% 2% 2% 1% <1% <1% <1% <1% <1% <1% <1% <1% <1%



Summary

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Lab Job No.: 16F-12151 **Client:** Apex Titan, Inc. - Dallas

Report Date: 09/26/2016 9:30 AM **Project:** Flower Mound HS Room 2575

Project #: 725010727032 **Sample Date:** 09/22/2016

Spore Trap Type: Zefon - Air-O-Cell Sample Type: Spore Trap, Non-cultured

Test Method: Mold: ASTM D7391-09 - Standard Profile Page 3 of 3

On 9/22/2016, three (3) samples were submitted by Clint Jech of Apex Titan, Inc. - Dallas (located at 12100 Ford. Rd., Suite 401, Farmers Branch, TX 75234) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification		ntration
3	150	Room 2575	Hyphal / Spore Fragments	53	21%
			Basidiospores	53	21%
			Myxomycete / Rust / Smut	33	13%
			Cladosporium	27	11%
			Aspergillus / Penicillium	27	11%
			Agaricales group	13	5%
			Ascospores	13	5%
			Coprinus group	7	3%
			Cercospora	7	3%
			Pithomyces	7	3%
			Alternaria	7	3%
			Total:	247	100%

Results may not be reported except in full. Data contained in this test report relates only to the samples tested. This report does not express or imply interpretation of

Moody Labs assumes no responsibility for the manner in which these samples were collected or handled prior to being received at this laboratory. Moody Labs assumes no responsibility for the qualifications of personnel performing sampling and/or interpretations of this data.

Analyst(s): Rebecca Lutz

Lab Director: Bruce Crabb

Lab Manager: Heather Lopez

Thank you for choosing Moody Labs

Approved Signatory: Bene Cult

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

SMLMS v11.83



Data Detail

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client: Apex Titan, Inc. - Dallas Lab Job No.: 16F-12151

Project: Flower Mound HS Room 2575 **Report Date:** 09/26/2016 9:30 AM

Project #: 725010727032 **Sample Date :** 09/22/2016

Sample Type: Spore Trap, Non-cultured Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:			1		2			3					
Location:	Exterior, North			Exterior			Room 2575						
Media Expires On:	Apr 2017			Apr 2017					Ap	or 2017			
Notes Included:	S	ee Ana	lytical Notes	S	S	ee Ana	lytical Notes	3					
Volume:			150				150		150				
	raw ct.	MDL	spores/m³		raw ct.	MDL	spores/m³		raw ct.	MDL	spores/m³		
Agaricales group	9	6.67	60	<1%	8	6.67	53	<1%	2	6.67	13	5%	
Alternaria	6	6.67	40	<1%	8	6.67	53	<1%	1	6.67	7	3%	
Ascospores	27	20.00	540	4%	42	20.00	840	5%	2	6.67	13	5%	
Aspergillus / Penicillium	56	20.00	1120	8%	41	20.00	820	5%	4	6.67	27	11%	
Basidiospores	105	50.00	5250	37%	115	66.67	7667	50%	8	6.67	53	21%	
Cercospora	66	6.67	440	3%	57	6.67	380	2%	1	6.67	7	3%	
Chaetomium													
Cladosporium	109	50.00	5450	38%	122	33.33	4066	26%	4	6.67	27	11%	
Coprinus group	5	6.67	33	<1%	11	6.67	73	<1%	1	6.67	7	3%	
Curvularia	12	6.67	80	<1%	13	6.67	87	<1%					
Drechslera / Bipolaris group	6	6.67	40	<1%	11	6.67	73	<1%					
Fusarium	35	6.67	233	2%	27	6.67	180	1%					
Ganoderma	7	6.67	47	<1%	4	6.67	27	<1%					
Hyphal / Spore Fragments	29	6.67	193	1%	35	6.67	233	2%	8	6.67	53	21%	
Memnoniella													
Myxomycete / Rust / Smut	56	6.67	374	3%	54	6.67	360	2%	5	6.67	33	13%	
Nigrospora	7	6.67	47	<1%	2	6.67	13	<1%					
Paecilomyces	39	6.67	260	2%	55	6.67	367	2%					
Pithomyces					2	6.67	13	<1%	1	6.67	7	3%	
Pyricularia	1	6.67	7	<1%									
Spegazzinia					2	6.67	13	<1%					
Stachybotrys													
Torula	1	6.67	7	<1%	7	6.67	47	<1%					
TOTALS	576		14221	100%	616		15365	100%	37		247	100%	
Analyst		Rebe	ecca Lutz		Rebecca Lutz				Rebecca Lutz				
Analysis Date		9/2	6/2016		9/26/2016					9/2	6/2016		
Debris Rating		3		3						4			
Debris Composition													
Fibers	1/5		2/5			1/5							
Inorganic/Other	3/5			3/5			3/5						
Insect Parts			1/5		1/5						1/5		
Pollen			2/5				2/5				0/5		
Skin/Dander			1/5				1/5				4/5		

End of Data Detail section

16F-12151 SMLMS v11.83



Analytical Notes

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client: Apex Titan, Inc. - Dallas Lab Job No.: 16F-12151

Project: Flower Mound HS Room 2575 Report Date: 09/26/2016 9:30 AM

Project #: 725010727032 **Sample Date :** 09/22/2016

Sample Type: Spore Trap, Non-cultured Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

Page 1 of 3

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Samples Analyzed

Sample No 1: Exterior, North

Notes: Please note: the minimum detection limit for Basidiospores is 50 spores / cubic meter. When comparing

results to other samples, use calculated results, not raw numbers.

Please note: the minimum detection limit for Cladosporium is 50 spores / cubic meter. When comparing

results to other samples, use calculated results, not raw numbers.

Sample No 2: Exterior

Notes: Please note: the minimum detection limit for Basidiospores is 67 spores / cubic meter. When comparing

results to other samples, use calculated results, not raw numbers.

Please note: the minimum detection limit for Cladosporium is 33 spores / cubic meter. When comparing

results to other samples, use calculated results, not raw numbers.

Field Blanks

No discernable field blanks were submitted with this set of samples.

NOTE: All remaining samples suitable for analysis.



Analytical Notes

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client: Apex Titan, Inc. - Dallas Lab Job No.: 16F-12151

Project: Flower Mound HS Room 2575 **Report Date:** 09/26/2016 9:30 AM

Project #: 725010727032 **Sample Date :** 09/22/2016

Sample Type: Spore Trap, Non-cultured Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile Page 2 of 3

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Methods

Method: ASTM D7391-09. A standard spore trap reading consists of a 30% reading for small spores; 100% of the sample is read for medium and large spores. A 100% reading is provided for containment samples, upon request, or otherwise as noted. Use final spore concentrations, not raw spore counts, for interpretation of results.

Calculation: Spores/cubic meter = (Raw spore count)*(MDL)

Note: MDL (Minimum Detection Limit) is calculated based upon 1 raw spore count.

Moody Labs recommends two significant figures for calculated values based on ASTM D7391-09.

This report must not be used by the customer to claim product certification, approval, or endorsement by AIHA, ISO, or any agency of the Federal Government.

Debris Rating Key

- 0 No linear trace detected
- 1 Trace particulate/debris
- 2 Light particulate/debris
- 3 Moderate particulate/debris.
- 4 Substantial particulate/debris
- 5 Extensive particulate/debris
- 6 Field blank
- 10 Hold Sample
- 11 Modified Analysis per Client Instructions

NOTE: Particulate/debris are defined as skin, fibers, pollen grains, insect parts, fungal and/or other non-fungal particles.

SMLMS v11.8



Analytical Notes

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Client: Apex Titan, Inc. - Dallas Lab Job No.: 16F-12151

Project: Flower Mound HS Room 2575 **Report Date:** 09/26/2016 9:30 AM

Project #: 725010727032 **Sample Date :** 09/22/2016

Sample Type: Spore Trap, Non-cultured Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile Page 3 of 3

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.



LAB#102577







DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

End of Analytical Notes section 16F-12151



Chain of Custody

GF -	12151-90C-3
Lab Job #	
Lab Job #_	
Lab Job #_	

			Lab Job #	
Please call in advan	ce for immediate, after-hour, &	weekend pricing	g & availability.	Page <u>/</u> of <u>/</u>
	2 day 3 day 5 day	Direct Exar Standard A	m Immediate	1 day
PCM Air (7400)	•	Expanded /		☐ 1 day ☐ 2 day
	2 day	Analyze Bi	anks 🗌 Yes	□ No
TOTAL DUST(0500/0600) ☐ 1 day [☐ 2 day	**Turnaround BACTERIA*		bject to Culture Growth**
Bulk ☐ 1 day [Water/Wipe/Micro Vac ☐ 1 day [☐ 2 day ☐ 3 day ☐ 5 day	CC + Gram	unts (CC) n Stain E. coli (P/A)	☐ 3 day ☐ 5 day ☐ 3 day ☐ 5 day ☐ 2-3 day ☐ 14 days
Billing Company / City: Apex	Titon Inc.		# of Sam	ples: 3
Submitter's Company:				ate: 9/22/2016
Submitter's Name: Clint 3				725010727032
Project: Flower Mound HS A Contact Information: Name: Clim				(071) 041 (071)
E-mail Results to: Clint/Darce				(972) 989-1031
Invoice Address: Veranice			P.O. #:	
*Please review paperwork and samples before submit Notes:				
Sample # Sample	e Description	Vol. / Area (if applicable)	Locatio	on / Notes
1 Exterior, North		150	T= 86.3 - H=.3	4.3 %
	***	150 7	T= 88.3 • H= 3	9.1 %
3 Room 2575	· · · · · · · · · · · · · · · · · · ·		= 75.5 · H= 37	
		<i>(</i>	Pilings = Cailing -	Tile
		la la	lais = Sheet Ro	K
		في ا	Hors = Carpt	+ Ille
	,			
Released By	Date / Time:	Received By	Yr. 10 0	Date / Time:
Released By:	9/27/2010 1324 Date / Time:	Received By:	Julys Lood	Date / Time:

ATTACHMENT 2

Mold Services Definitions & Limitations/Standard of Care and Reliance





Mold Services Definitions & Limitations

"Mold" defined. Mold is a general term used to describe various types of singled-celled naturally occurring biological organisms occurring worldwide. For purposes of this report the term "mold" is broadly defined to include any living or dead fungi or related products or parts, including spores, hyphae, and mycotoxins.

Limited Scope of Mold Assessment. The scope of Apex's mold assessment services as reflected in the Proposal and this report are limited in that (i) they were physically limited to certain portions of the building structure (e.g., the Client identified Investigation Areas); and (ii) limited by accessibility to building materials or components within the Investigation Area(s). In contrast to a Limited Assessment" is a comprehensive assessment, which involves destructive sampling methods and the scope of the assessment typically extending to the entire building structure.

Time sensitive. Mold assessments are essentially a "snap shot in time," and the results are only relevant at the time of site reconnaissance. Because mold, when biologically active, is a living organism, its presence is influenced and controlled by environmental conditions. Mold assessments, therefore, are "time sensitive" in that the presence and concentration of mold and similar organisms in building structures or in the air is directly influenced by environmental conditions (such as humidity, moisture, nutrients and substrates), whether natural or caused by man, which conditions may vary significantly over relatively short periods of time.

Methodologies. Currently, mold assessment methodologies and protocols are governed by persuasive guidelines (rather than promulgated federal/state or local regulations). Presently, there is no data that supports a threshold limit or dose-response relationship for exposure to mold aeroallergens, individual pathogens, opportunistic pathogens and/or mycotoxins. The Occupational Safety and Health Administration (OSHA), the National Institute of Occupational Safety and Health (NIOSH) and other non-governmental associations, have not yet established permissible exposure limits (PELs), recommended exposure limits (RELs), or other limit values for aeroallergens. Because no limit values presently exist, Apex will not and cannot represent that the site contains no harmful microbes, mold, fungi, or their metabolites, or other latent conditions beyond those identified by the limited scope of this mold assessment.

Findings limited. Findings from a limited mold assessment are limited because of the nature of the information obtained (e.g., visual reconnaissance of readily accessible areas of building structures, interview information, anecdotal information, and limited sampling data derived from one or more specific sampling events). Apex cannot warrant the accuracy of prior or subsequent information/data, reports and services performed by other firms at the Site. Apex assumes no responsibility or liability for errors in information or data provided by or through the client or third party sources. Apex's services are not to be construed as legal or medical interpretation or advice.

Moisture Intrusion Limitation. Apex performs mold assessment services and is not a moisture intrusion, HVAC, roofing, plumbing or building envelope specialist. However, during the course of conducting its mold assessment services, Apex will report observed areas of apparent moisture intrusion. Apex does not and will not investigate the cause or causes of such observed moisture intrusion. In the event apparent moisture intrusion is observed, Apex will recommend

that the client contact a specialist (i.e., plumbing contractor, building envelope specialist, HVAC contractor, water intrusion specialist, etc.) to assist the client in determining the specific cause or causes of the moisture intrusion and remedial options.

Standard of Care

Apex performed its Services in accordance with generally accepted practices of the profession undertaken in similar services at the same time and in the same geographical area. No other warranties, expressed or implied, apply to the Services hereunder or this report.

Reliance

Apex's proposal for this project, services and this report have been prepared on behalf of and for the exclusive use of Lewisville Independent School District solely for their use and reliance in assessing the presence of mold in the Investigation Areas of the site. Lewisville Independent School District is the only party to which Apex explained the risks and limitations of the services and was solely involved in shaping the scope of services. Accordingly, reliance on this report by any other party may involve assumptions leading to an unintended interpretation of findings and opinions. With the consent of the client, Apex may offer reliance to third parties or contract with other parties to develop findings and opinions related to such party's unique risk management concerns. Notwithstanding the foregoing, reliance by any and all third parties upon the proposal, the Services or this report shall be limited in the aggregate to all relying parties to the fair market value of the Services provided by Apex.

