

COMMITTED TO EXCELLENCE

DATE: April 1, 2013

TO: Dr. Patrick Schott, Principal

SUBJECT: Forest Vista ES - IAQ - Air Test results - Nurses' Office

On Thursday 3/28, SWG Air tested the Nurses' Office. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Nurses' Office, was **13.3%** of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
Lewisville ISD
469-446-8882