

COMMITTED TO EXCELLENCE

DATE: May 16, 2013

TO: Julie Sheriff, Principal

SUBJECT: Southridge ES - IAQ - Air Retest Results - Music Room

On Tuesday 5/14, SWG retested the Music Room. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Music Room, was **7.2%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
Lewisville ISD
469-446-8882