

DATE: August 23, 2013

TO: Jennifer Spitzer, Principal

SUBJECT: B. B. Owen ES - IAQ - Air Test Results report - Library

On Wednesday 8/21, SWG Air tested the Library. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Library, was **4.3%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,

Paul

Paul Siddall
Special Projects Manager (IAQ)
Facility Services
Lewisville ISD
469-446-8882