

**DATE:** September 10, 2013

**TO:** Dr. Sharon Heier, Principal

**SUBJECT:** Timber Creek ES - IAQ - Air Test Results - Rooms 303, 304 & 404

On Friday 8/23, SWG Air tested the Rooms 303, 304 and 404. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Room 303, was 7.1%, Room 304, was 5.9%, and Room 404, was 5.8% of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Special Projects Manager (IAQ)  
Facility Services  
Lewisville ISD  
469-446-8882