

September 24, 2012

Lewisville Independent School District
340 Lake Haven
Lewisville, Texas 75057
Attn: Mr. Paul Siddall

Re: Limited Mold Assessment Services
Forest Vista Elementary School
Room 510
900 Forest Vista Drive
Flower Mound, Texas,
SWG Project No. 0112248

Introduction

Southwest Geoscience (SWG) conducted limited mold assessment activities for the Lewisville Independent School District (Lewisville I.S.D.) within room 510 at Forest Vista Elementary School located at 900 Forest Vista Drive in Flower Mound, Texas (hereinafter referred to as the "Site"). The investigation was limited to areas of the Site identified by Lewisville I.S.D. as described below. The assessment was performed by Mr. Clinton S. Jech a State of Texas licensed Mold Assessment Technician (License No. MAT1075) on September 21, 2012. SWG's mold services definitions and limitations are included as an attachment to this report.

Investigation Areas

Lewisville I.S.D. identified the following physical portions of the Site as the target investigation areas ("Investigation Areas") for mold assessment: readily accessible areas within room 510. SWG's mold assessment services were limited to the Investigation Area(s) identified by Lewisville, I.S.D. Additional areas or portions of the Site were out-of-scope and not included in SWG's mold assessment or this report at this time.

Scope of Work

As set forth in SWG's Mold Assessment Proposal (No. 01121315) dated September 11, 2012, SWG's scope-of-work was to provide visual and/or analytical mold assessment and related services in the Investigation Areas which included:

Visual Reconnaissance: SWG performed a visual reconnaissance of the Investigation Areas for visible indications of moisture intrusion (as indicated by staining or visible moisture) and/or suspect mold growth. SWG's visual reconnaissance only included readily accessible or visible portions of the Investigation Areas.

Suspect Mold Growth Sampling and Analysis: SWG collected limited ambient air samples for nonviable mold spores utilizing Air-O-Cell cassettes. "Air-O-Cell" refers to slit impaction air sampling cassettes manufactured by Zefon Analytical Accessories, St. Petersburg, Florida.

Site Reconnaissance Observations/Findings and Recommendations

SWG's Mold Assessment Site reconnaissance was performed on September 21, 2012 by Mr. Clinton S. Jech. SWG's visual reconnaissance of the Investigation areas revealed the following:

Temperature and Relative Humidity

Temperature readings collected inside the room was reported as 82.9 degrees Fahrenheit while relative humidity was reported as 34.1 percent. Temperature readings collected outside the building ranged from 91.7 to 98.4 degrees Fahrenheit while outside relative humidity ranged from 21.5 to 24.5 percent.

Relative humidity is a measure of the moisture content of air and is closely tied to the comfort of the office/workplace temperature. As with temperature, there are no regulations governing acceptable office/workplace humidity ranges. Humidity levels in the office/work place are not only related to health effects, but also have operational impacts on modern office equipment.

Workplace/office temperatures have historically been considered a subjective factor because the perception of uncomfortable temperature levels is specific to each individual. There are no regulations governing acceptable office/workplace temperature ranges, but significant research has been conducted which indicates that there are temperature ranges that are not only comfortable but also result in optimum performance. ASHRAE (American Society of Heating, Refrigerating & Air Conditioning Engineers) has published guidelines describing thermal environmental conditions that at least 80% of the persons who occupy that environment will find acceptable or "comfortable." Table I below explains the applicable limits and guidelines.

Relative Humidity	Winter Temperatures	Summer Temperatures
30%	68.5 to 76°F	74 to 80°F
40%	68.5 to 75.5°F	73 to 79.5°F
50%	68.5 to 74.5°F	73 to 79°F
60%	68 to 74°F	72.5 to 78°F

SWG utilized a Protimeter Moisture Measurement System (MMS) instrument (Model No. BLD2000) to measure and diagnose dampness in the drywall within random areas. The MMS is a battery powered handheld unit that is equipped with hydrostick probes to measure moisture content in wood, drywall and other and non-conductive materials. The device measures electrical conductivity of building materials and compares the conductivity readings to an internal, electronic standard reading for normal or "dry" materials.

Moisture content readings were obtained by pushing the moisture probe pins into surfaces. The measured values were then displayed on a colored scale depicting if the materials measured were normal (dry), higher than normal but not critical (at risk) or contained excessive moisture levels (wet). Based on the manufacturer's guidelines, the instrument measurement values are described below:

< 5%	Out of Range
> 5% but < 16%	Normal
> 17% but < 20%	Higher than Normal but Not Critical
> 20%	Excessive Moisture Levels

Moisture meter readings taken from the walls within the room ranged from 10 - 16% which is considered normal by the manufacturer.

Air Monitoring Results

SWG collected one (1) sample from the interior of the building and two (2) samples from the exterior of the building. The microbial samples were analyzed by Steve Moody Micro Services, Inc. (SMMS) in Farmers Branch, Texas; SMMS is a State of Texas licensed mold analysis laboratory and accredited under the AIHA Laboratory Quality Assurance Program for Environmental Microbiology.

Air testing performed using spore traps found that airborne mold spores in the room was considerably lower and were qualitatively similar to those measured outside of the building at the time the sampling was performed. Total fungal spore concentration within the investigation area was reported as 6,960 counts/m³ while the exterior level ranged from 20,760 to 27,400 counts/m³.

Room 510

Four (4) types of mold were identified at a higher concentration within room 510 as compared to the sample collected from the exterior of the building. Curvularia was reported as 460 counts/m³ while no exterior levels were reported. Myxomycete/Periconia/Rust/Smut was reported as 620 counts/m³ while exterior levels were reported as 320 counts/m³. Nigrospora was reported as 40 counts/m³ while no exterior counts were reported. Stachybotrys was reported as 60 counts /m³ while no exterior counts were reported.

The American Conference of Governmental Industrial Hygienists (ACGIH) sets forth assessment criteria related to the "indoor/outdoor" relationship where the indoor air quality should be at or below that of outdoor air quality with regard to fungal spores (see ACGIH Bioaerosols, Assessment and Controls publication, 1999).

Suspect Mold

SWG observed no visible mold during the assessment.

Conclusions and Recommendations

Based on SWG's limited assessment and the analytical results, SWG recommends that the room be cleaned and retested. If you have any questions regarding this report or if we can assist you with any other matter, please contact the undersigned at (214) 350-5469.

If you have any questions regarding this report or if we can assist you with any other matter, please contact the undersigned at (214) 350-5469.

Sincerely,
Southwest Geoscience



Darren G. Bowden
Corporate Director
Industrial Hygiene Services
Texas Mold Assessment Consultant
Lic. No. MAC0321

Attachments: Analytical Results/Chain of Custody
Mold Services Definitions & Limitations/Standard of Care and Reliance

Analytical Results/Chain of Custody

IAQ Mold Report

Steve Moody Micro Services, LLC

2051 Valley View Lane

Farmers Branch, TX 75234 Phone: (972) 241-8460

Summary

DSHS License No.: LAB0117

AIHA EMPAT ID: 102577

Client : Southwest Geoscience - Dallas, TX

Lab Job No. 12F-11482

Project : Forest Vista ES, Room 510

Report Date 09/24/2012 2:17 PM

Project # : 0112248

Sample Date : 09/21/2012

Sample Type: Spore Trap, Non-cultured

Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

Page 1 of 2

On 9/21/2012, three (3) samples were submitted by Clint Jech of Southwest Geoscience - Dallas, TX (located at 2351 W NW Hwy #3321, Dallas, TX 75220) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter			
1	75	Exterior, East	Agaricus / Agrocybe	320			
			Alternaria	920			
			Ascospores	480			
			Aspergillus / Penicillium	6680			
			Basidiospores	7480			
			Cercospora / Pseudocercospora	80			
			Cladosporium	8640			
			Drechslera / Bipolaris group	120			
			Ganoderma	120			
			Hyphal / Spore Fragments	2160			
			Myxomycete / Periconia / Rust / Smut	320			
			Pithomyces	80			
						Total:	27400
2	75	Exterior, South * See Analytical Notes report for further details	Agaricus / Agrocybe	240			
			Alternaria	1480			
			Ascospores	280			
			Aspergillus / Penicillium	2920			
			Basidiospores	5280			
			Cercospora / Pseudocercospora	160			
			Cladosporium	7560			
			Coprinus	160			
			Drechslera / Bipolaris group	200			
			Hyphal / Spore Fragments	2240			
			Myxomycete / Periconia / Rust / Smut	240			
						Total:	20760

IAQ Mold Report

Steve Moody Micro Services, LLC
 2051 Valley View Lane
 Farmers Branch, TX 75234 Phone: (972) 241-8460

Summary

DSHS License No.: LAB0117
 AIHA EMPAT ID: 102577

Client : Southwest Geoscience - Dallas, TX **Lab Job No.** 12F-11482
Project : Forest Vista ES, Room 510 **Report Date** 09/24/2012 2:17 PM
Project # : 0112248 **Sample Date :** 09/21/2012
Sample Type: Spore Trap, Non-cultured **Spore Trap Type:** Zefon - Air-O-Cell
Test Method: Mold: ASTM D7391-09 - Standard Profile Page 2 of 2

On 9/21/2012, three (3) samples were submitted by Clint Jech of Southwest Geoscience - Dallas, TX (located at 2351 W NW Hwy #3321, Dallas, TX 75220) for Spore Trap, Non-cultured mold analysis. This report consists of three sections; a summary section, a data detail section, and an analytical notes section.

Sample Number	Volume (liters)	Sample Description	Identification	Concentration spores/cubic meter
3	150	Room 510 * See Analytical Notes report for further details	Alternaria Ascospores Aspergillus / Penicillium Basidiospores Cladosporium Coprinus Curvularia Drechslera / Bipolaris group Hyphal / Spore Fragments Myxomycete / Periconia / Rust / Smut Nigrospora Stachybotrys <div style="text-align: right;">Total:</div>	460 200 820 1840 1140 80 460 120 1120 620 40 60 6960


Results may not be reported except in full. Data contained in this test report relates only to the samples tested. This report does not express or imply interpretation of the results contained herein. Interpretation should be made by a qualified professional.

Steve Moody Micro Services assumes no responsibility for the manner in which these samples were collected or handled prior to being received at this laboratory. SMMS assumes no responsibility for the qualifications of personnel performing sampling and/or interpretations of this data.

Analyst(s): Rob Greene

Lab Director: Steve Moody

Approved Signatory :



Thank you for choosing Steve Moody Micro Services

IAQ Mold Report

Steve Moody Micro Services, LLC
 2051 Valley View Lane
 Farmers Branch, TX 75234 Phone: (972) 241-8460

Data Detail

DSHS License No.: LAB0117
 AIHA EMPAT ID: 102577

Client : Southwest Geoscience - Dallas, TX **Lab Job No. :** 12F-11482
Project : Forest Vista ES, Room 510 **Report Date :** 09/24/2012 2:17 PM
Project # : 0112248 **Sample Date :** 09/21/2012
Sample Type: Spore Trap, Non-cultured **Spore Trap Type:** Zefon - Air-O-Cell
Test Method: Mold: ASTM D7391-09 - Standard Profile Page 1 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Sample ID:	1			2			3					
Location:	Exterior, East			Exterior, South			Room 510					
Debris Rating:	4			5			5					
Media Expires On:	May 2013			May 2013			May 2013					
Notes Included?:												
Volume:	75			75			150					
	raw ct.	MDL	spores/m ³	raw ct.	MDL	spores/m ³	raw ct.	MDL	spores/m ³			
Agaricus / Agrocybe	8	40.00	320	6	40.00	240						
Alternaria	23	40.00	920	37	40.00	1480	23	20.00	460			
Ascospores	12	40.00	480	7	40.00	280	10	20.00	200			
Aspergillus / Penicillium	167	40.00	6680	73	40.00	2920	41	20.00	820			
Basidiospores	187	40.00	7480	132	40.00	5280	92	20.00	1840			
Cercospora / Pseudocercospora	2	40.00	80	4	40.00	160						
Chaetomium												
Cladosporium	216	40.00	8640	189	40.00	7560	57	20.00	1140			
Coprinus				4	40.00	160	4	20.00	80			
Curvularia							23	20.00	460			
Drechslera / Bipolaris group	3	40.00	120	5	40.00	200	6	20.00	120			
Ganoderma	3	40.00	120									
Hyphal / Spore Fragments	54	40.00	2160	56	40.00	2240	56	20.00	1120			
Memnoniella												
Myxomycete / Periconia / Rust / Smut	8	40.00	320	6	40.00	240	31	20.00	620			
Nigrospora							2	20.00	40			
Non-specified Fungal Spore(s)												
Pithomyces	2	40.00	80									
Pollen												
Stachybotrys							3	20.00	60			
TOTALS	685		27400	519		20760	348		6960			
Analyst	Rob Greene			Rob Greene			Rob Greene					
Analysis Date	9/24/2012			9/24/2012			9/24/2012					

IAQ Mold Report

Steve Moody Micro Services, LLC
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Data Detail

DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Southwest Geoscience - Dallas, TX

Lab Job No. : 12F-11482

Project : Forest Vista ES, Room 510

Report Date : 09/24/2012 2:17 PM

Project # : 0112248

Sample Date : 09/21/2012

Sample Type: Spore Trap, Non-cultured

Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

Page 2 of 2

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Debris Rating Key:

- 0 - No debris detected.
- 1 - Trace debris.
- 2 - Light debris.
- 3 - Moderate debris.
- 4 - Substantial debris.
- 5 - Extensive debris.
- 6 - Field blank.

NOTE: Debris defined as skin, fibers, pollen grains, insect parts, and/or other non-fungal particles.

IAQ Mold Report

Steve Moody Micro Services, LLC
2051 Valley View Lane
Farmers Branch, TX 75234 Phone: (972) 241-8460

Analytical Notes

DSHS License No.: LAB0117
AIHA EMPAT ID: 102577

Client : Southwest Geoscience - Dallas, TX

Lab Job No. : 12F-11482

Project : Forest Vista ES, Room 510

Report Date : 09/24/2012 2:17 PM

Project # : 0112248

Sample Date : 09/21/2012

Sample Type: Spore Trap, Non-cultured

Spore Trap Type: Zefon - Air-O-Cell

Test Method: Mold: ASTM D7391-09 - Standard Profile

Page 1 of 1

This report consists of three sections; a summary section, a data detail section, and an analytical notes section. Results may not be reported except in full.

Samples Analyzed

Sample No: 2 : Exterior, South

Notes: 20% Occluded.

Sample No: 3 : Room 510

Notes: 80% Occluded.

Field Blanks

No discernable field blanks were submitted with this set of samples.

NOTE: All remaining samples suitable for analysis.

Methods

Method: ASTM D7391-09: Categorization and Quantification of Airborne Fungal Structures in an Inertial Impaction Sample by Optical Microscopy.

Calculation: Spores/cubic meter = (Raw spore count)*(MDL)

Note: MDL (Minimum Detection Limit) is calculated based upon 1 raw spore count.

Steve Moody Micro Services recommends two significant figures for calculated values based ASTM D7391-09.



LAB # 102577



Lab Job # 12F-11482 AOC: 3
 Lab Job # _____
 Lab Job # _____

Please call in advance for immediate, after-hour, & weekend pricing & availability.

Turnaround of Culture Samples subject to Culture Growth

ASBESTOS PLM

Bulk 1 day 2 day 3 day 5 day Immediate
 Analyze All Positive Stop

LEAD Paint / Soil / Wipe 1 day 2 day 3 day 5 day Immediate
PCM Air (7400) 1 day 2 day 3 day 5 day Immediate
TOTAL DUST (0500/0600) 1 day 2 day

MOLD

Non-culture (Tape / Bulk / (Air)) 1 day 2 day Immediate
 Air Standard Profile Air Expanded Profile
 Analyze Blanks Yes No
 Culture (Swab / Bulk / Plate) 7-14 day

ASBESTOS TEM

Air AHERA Method 6 hr 12hr 24 hr
 Air 7402 (Modified) 1 day 2 day 3 day
 Bulk/Wipe/Micro Vac 1 day 2 day 3 day
 Water 1 day 2 day 3 day
 Analyze Blanks Yes No

BACTERIA

Heterotrophic Plate Count (HPC) 3 day
 HPC + Gram Stain 3 day 5 day
 HPC + 3 Gram Neg ID 6-8 day
 HPC + 5 Gram Neg ID 6-8 day
 Fecal Coliform (MPN) 3 day
 Total Coliform & E Coli (P/A) 2-3 day

Billing Company / City: SWG # of Samples: 3
 Submitter / Company: Clinton S. Jech Sample Date: 9/21/2012
 Project: Forest Vista ES Room 510 Project #: 0112248
 Contact Information: Name: Clint Jech Phone #: _____
 E-mail Results to: Clint@Duxma/Veronica Mobile #: 972 989-1031
 Invoice Address: Veronica P.O. #: _____

— Please review paperwork and samples before submitting to lab. Unsealed / improperly packaged samples or excessive administrative requests may incur additional fees—

Notes:

Sample #	Sample Description	Vol. / Area if applicable	Location / Notes
1	Exterior, East	75	
2	Exterior, South	75	
3	Room 510	150	

Released By: <u>[Signature]</u>	Date / Time: <u>9/21/2012 1:50</u>	Received By: <u>Candice Luna</u>	Date / Time: <u>9-21-12 3:49 PM</u>
Released By:	Date / Time:	Received By:	Date / Time:

Mold Services Definitions & Limitations/
Standard of Care and Reliance

Mold Services Definitions & Limitations

“Mold” defined. Mold is a general term used to describe various types of single-celled naturally occurring biological organisms occurring worldwide. For purposes of this report (and the Texas Mold Assessment & Remediation Rules), the term “mold” is broadly defined to include any living or dead fungi or related products or parts, including spores, hyphae, and mycotoxins.

Limited Scope of Mold Assessment. The scope of SWG’s mold assessment services as reflected in the Proposal and this report are limited in that (i) they were physically limited to certain portions of the building structure (e.g., the Client identified Investigation Areas); and (ii) limited by accessibility to building materials or components within the Investigation Area(s). In contrast to a Limited Assessment” is a comprehensive assessment, which involves destructive sampling methods and the scope of the assessment typically extending to the entire building structure.

Time sensitive. Mold assessments are essentially a “snap shot in time,” and the results are only relevant at the time of site reconnaissance. Because mold, when biologically active, is a living organism, its presence is influenced and controlled by environmental conditions. Mold assessments, therefore, are “time sensitive” in that the presence and concentration of mold and similar organisms in building structures or in the air is directly influenced by environmental conditions (such as humidity, moisture, nutrients and substrates), whether natural or caused by man, which conditions may vary significantly over relatively short periods of time.

Methodologies. Currently, mold assessment methodologies and protocols in Texas are governed by persuasive guidelines (rather than promulgated federal/state or local regulations). Presently, there is no data that supports a threshold limit or dose-response relationship for exposure to mold aeroallergens, individual pathogens, opportunistic pathogens and/or mycotoxins. The Occupational Safety and Health Administration (OSHA), the National Institute of Occupational Safety and Health (NIOSH) and other non-governmental associations, have not yet established permissible exposure limits (PELs), recommended exposure limits (RELs), or other limit values for aeroallergens. Because no limit values presently exist, SWG will not and cannot represent that the site contains no harmful microbes, mold, fungi, or their metabolites, or other latent conditions beyond those identified by the limited scope of this mold assessment.

Findings limited. Findings from a limited mold assessment are limited because of the nature of the information obtained (e.g., visual reconnaissance of readily accessible areas of building structures, interview information, anecdotal information, and limited sampling data derived from one or more specific sampling events). SWG cannot warrant the accuracy of prior or subsequent information/data, reports and services performed by other firms at the Site. SWG assumes no responsibility or liability for errors in information or data provided by or through the client or third party sources. SWG’s services are not to be construed as legal or medical interpretation or advice.

Moisture Intrusion Limitation. SWG performs mold assessment services and is not a moisture intrusion, HVAC, roofing, plumbing or building envelope specialist. However, during the course of conducting its mold assessment services, SWG will report observed areas of apparent moisture intrusion. SWG does not and will not investigate the cause or causes of such observed moisture intrusion. In the event apparent moisture intrusion is observed, SWG will recommend that the client contact a specialist (i.e., plumbing contractor, building envelope specialist, HVAC contractor, water intrusion specialist, etc.) to assist the client in determining the specific cause or causes of the moisture intrusion and remedial options.

Texas Licensing Requirements. SWG (and/or its personnel) will render the services set forth in this proposal in the capacity of a Texas licensed Mold Assessor. SWG is not licensed as a Mold Remediation Contractor and does not perform mold remediation. As of January 1, 2005, Texas law has required that Mold Assessors and Mold Remediation Contractors be licensed.

Mold Remediation Certificate. For mold remediation projects (above certain size thresholds), applicable Texas law (i.e., Texas Occupation Code Section 1958.54 and T.A.C. Section 295.397 (the Texas Mold Assessment and Remediation Rules), requires that a "Certificate of Mold Remediation" be issued by the Mold Remediation Contractor upon successful completion of the project. This certificate must be provided to property owners no later than the 10th day after the date on which the mold remediation is completed at a property. The Mold Remediation Certificate issued by the Mold Remediation Contractor must include a certification by the Mold Assessor that the mold remediation project has been successfully completed in accordance with the mold remediation protocol.

Be advised that SWG's issuance of a Mold Remediation Certificate upon successful completion of a Mold Remediation project does not mean, warrant or otherwise guarantee that mold will not be subsequently found in any portion of the Investigation Area or the Site. In the event that SWG is engaged to render services in connection with a mold remediation project, SWG will require *Client to provide to SWG a signed certificate prepared by Client's moisture intrusion specialist or appropriate contractor stating that all sources of moisture which resulted in the presence of mold in the Investigation Area have been fully remediated and corrected.*

Standard of Care

SWG performed its Services in accordance with generally accepted practices of the profession undertaken in similar services at the same time and in the same geographical area. No other warranties, expressed or implied, apply to the Services hereunder or this report.

Reliance

SWG's proposal for this project, services and this report have been prepared on behalf of and for the exclusive use of Lewisville Independent School District solely for their use and reliance in assessing the presence of mold in the Investigation Areas of the site. Lewisville Independent School District is the only party to which SWG explained the risks and limitations of the services and was solely involved in shaping the scope of services. Accordingly, reliance on this report by any other party may involve assumptions leading to an unintended interpretation of findings and opinions. With the consent of the client, SWG may offer reliance to third parties

or contract with other parties to develop findings and opinions related to such party's unique risk management concerns. Notwithstanding the foregoing, reliance by any and all third parties upon the proposal, the Services or this report shall be limited in the aggregate to all relying parties to the fair market value of the Services provided by SWG.
