

COMMITTED TO EXCELLENCE

DATE: September 28, 2012

TO: Dr. Patrick Schott, Principal

SUBJECT: Forest Vista ES - Air Test results - Room 510

On Friday 9/21, SWG Air tested the Room 510. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Room 510, was **25.4%** of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. **There were 3 spores of Stachybotrys. I will make arrangements with Custodial to Steam Clean the carpet, then we will retest.** If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
469-446-8882