

COMMITTED TO EXCELLENCE

**DATE:** September 28, 2012

**TO:** Barbara Hamric, Principal

**SUBJECT:** Hedrick MS - IAQ - Air Test results - Room 4215

On Friday 9/21, SWG Air tested the Room 4215. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Room 4215, was **14.5%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Special Projects (IAQ)  
Facility Services  
469-446-8882