

COMMITTED TO EXCELLENCE

DATE: October 4, 2012

TO: Toby Maxson, Principal

SUBJECT: Heritage ES - IAQ - Air Test results - Rooms A-15, A-16, A-17, A-18, A-19, A-20, B-12, B-13 & Counselor's office

On Friday 9/12, SWG Air tested Rooms A-15, A-16, A-17, A-18, A-19, A-20, B-12, B-13 & Counselor's office. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Room A-15, was **30.1%**, Room A-16, was **14.4%**, Room A-17, was **23.6%**, Room A-18, was **1.5%**, Room A-19, was **5.7%**, Room A-20, was **5.4%**, Room B-12, was **23.9%**, Room B-13, was **3.6%**, and the Counselor's office, was **5.7%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. **Rooms A-19, A-20, B-13 and the Counselor's office had 1 to 5 spores of Stachybotrys. I will make arrangements with Custodial, to steam clean those rooms this Friday night 10/5. Then the middle of next week, we will retest.** If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
Facility Services
469-446-8882