

**DATE:** May 13, 2014

**TO:** Michael Vargas, Assistant Principal

**SUBJECT:** Hebron HS - IAQ - Air Test - Dressing Room E-Coaches' Office

This morning 5/13, I received a call from Alex Del Rio, to meet and check the Coaches' Office in Dressing Room E. After our inspection and discussion, I will be requesting an Air Test for this Friday 5/16. We should have the results back by Monday 5/19. If you have any questions, please contact me.

Thanks,  
Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
469-446-8882

**DATE:** July 28, 2014

**TO:** Michael Vargas, Assistant Principal

**SUBJECT:** Hebron HS - IAQ - Air Test results - Coach's office & East Dressing room

On Wednesday 7/23, SWG Air tested the Coach's office and the East Dressing room. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Room A-127, was **15.5%**, East Dressing room, was **9.6%** of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,

Paul

Paul Siddall  
Maintenance Energy Auditor (IAQ)  
Facility Services  
Lewisville ISD  
469-446-8882