

DATE: April 29, 2014

TO: Scot Finch, Principal

SUBJECT: Hebron HS - IAQ - Initial Contact - Nurses' Office

Yesterday evening 4/28, I received a phone call from Alex Del Rio, in regards to the Nurses' Office. Behind the refrigerator, there has been a small water leak, which has since been repaired. Some of the baseboard has a small amount of mold. This morning at 7:15 4/29, I met Alex there along with Michael Vargas. I requested the East Zone to remove and clean the baseboards, and cut about 12"s high and 4ft long of sheet rock and replace. Alex said that they could get it done today and tomorrow. Once the repair is made, I will have the room Air Tested.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
469-446-8882

DATE: July 24, 2014

TO: Michael Vargas, Assistant Principal

SUBJECT: Hebron HS - IAQ - Air Test report - Nurse's office

On Monday 7/21, SWG Air tested the Nurse's office. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Nurse's office, was 3.4% of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
469-446-8882