

DATE: August 26, 2014

TO: Dulia Longoria, Principal

SUBJECT: Lillie Jackson - IAQ - Air Test results - Music Room

On Thursday 8/21, Apex-Titan Air tested the Music room. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Music room, was 2.0% of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
469-446-8882