

DATE: January 29, 2014

TO: Kelly Hayunga, Principal

SUBJECT: Old Settlers ES - IAQ - Initial contact - Nurse's restroom

This morning 1/29, I received Work Order: #176594: "*There is a strong moldy smell in the nurse's bathroom.*" This afternoon 1/29, I inspected the area and talked to the Nurse. There were no indications of water intrusion in the restroom. Asked if water had been poured down the floor drain in the last month, and it had not, so I poured about a gallon of water down the drain. I will go back Friday 1/31 at 7:00 AM and check for smell.

If you have any questions, please contact me.

Thanks,

Paul

Paul Siddall
Maintenance Energy Auditor (IAQ)
Facility Services
Lewisville ISD
469-446-8882